

PROPOSED CONSTRUCTION
BEDS & SPACE PROGRAM
MILITARY HEALTH CARE FACILITY
NAVAL REGIONAL MEDICAL CENTER
HOSPITAL MODERNIZATION/ADDITION
PORTSMOUTH, VIRGINIA
FY 1981

PROPOSED CONSTRUCTION
BEDS & SPACE PROGRAM

MILITARY HEALTH CARE FACILITY

NAVAL REGIONAL MEDICAL CENTER
HOSPITAL MODERNIZATION/ADDITION

PORTSMOUTH, VIRGINIA

FY 1981

NAVAL REGIONAL MEDICAL CENTER
BUILDING 215 - HOSPITAL
PORTSMOUTH, VIRGINIA




TABLE OF CONTENTS

	<u>PAGE</u>
A. Bed Needs - 1981 Portsmouth Hospital.....	1 - 6
B. Outpatient & Meals Facilities Utilization.....	7 - 8
C. Proposed Breakdown of Beds.....	9
D. History of Beds & Square Footage Needs.....	10
E. Training Facilities.....	11
F. Fact Sheet.....	12
G. Space Program (First Run).....	13-57
H. Design Planning Data - Beds.....	58-59
I. Design Planning - Existing Building Expansion and New Construction Criteria.....	60-61
J. 1391, P-002, Hospital Addition/Alteration of 10 Dec 1976.....	62-63
K. 1391, P-002 (Consolidated) Center Modernization of 10 Dec 1976.....	64-65

1981 PORTSMOUTH HOSPITAL--BED NEEDS

Acute Care ¹	594
Light Care: 37.5% ² x 594 =	223
Alcohol Rehabilitation Unit Needs	<u>15</u>
Total Beds	<u>832</u>

¹25% of these beds are single-bed rooms, expandable to two-bed rooms.

²The accepted DOD percent (see San Diego Study), which was 800 acute care beds vs. 300 light care beds - 37.5%.

1981 PORTSMOUTH HOSPITAL

ACUTE BEDS--REQUIREMENTS--RECAPITULATION

<u>BENEFICIARY CATEGORY</u>	<u>ADPL</u>	<u>PLUS DISPERSION</u>			<u>BEDS</u>
Active Duty	236	+	59	=	295
Dependents of Active Duty - Direct Care	145	+	36	=	181
CHAMPUS ¹	51	+	13	=	<u>64</u>
Subtotal					540
Retired, Dependents of Retired, and Deceased ²		+	10% of 540	=	<u>54</u>
Total Acute Beds					<u><u>594</u></u>

¹A calculation to justify that these military beds are used more economically than civilian beds, to follow.

²The 10% is a DOD limitation.

PORTSMOUTH HOSPITAL--EXPECTED² ADPL¹

	<u>1975 Patient Days</u>		<u>Personnel Loading</u>		<u>1981 Expected³</u>	<u>1981 Expected⁴</u>
	<u>Actual</u>	<u>Expected</u>	<u>1975</u>	<u>1981</u>	<u>Patient Days</u>	<u>ADPL</u>
Active Duty	186,415	76,356	88,800	97,914	85,986	236
Dependents						
Active Duty	45,807	48,253	127,237	139,752	52,999	145

¹ADPL - Average Daily Patient Load (Patients a Day).

²By using the "expected" patient days in calculations, the results in terms of "beds" are only "acute care beds," after application of dispersion factor; i.e., expected ADPL x Dispersion Factor = Acute Care Beds

³ $\frac{\text{Personnel Loading 1981}}{\text{Personnel Loading 1975}} \times 1975 \text{ Expected Patient Days.}$

⁴1981 Expected Patient Days divided by 365 days/year = Expected Patients a Day (ADPL).

PORTSMOUTH HOSPITAL

CHAMPUS WORKLOAD--DEPENDENTS OF ACTIVE DUTY--ADPL

HOSPITAL DAYS¹

CHAMPUS Workload
1/1/75 to 12/31/75

17,409

Completed Billing During
Reporting Period Only = 91.7%

Calculation Hospital Days = $\frac{17,409}{91.7\%} = 18,985$

Recoverable CHAMPUS Workload:

Assume 90% Recoverable: $90\% \times 18,985 = 17,087$ Hospital Days

Projected to 1981: $17,087 \times \frac{139,752 \text{ (Dependents of ACDU - 1981)}}{127,237 \text{ (Dependents of ACDU - 1976)}} =$

18,768: Patient Days - 1981 Projection

ADPL: $\frac{18,768 \text{ Projected 1981 Patient Days}}{365 \text{ Days}} = 51 \text{ Patients a Day}$

¹From OCHAMPUS, Denver, printout of 1975 Calendar Year titled "All CHAMPUS User Beneficiaries for Period 01/01/75 through 12/31/75." A teaching hospital such as Portsmouth Hospital will provide all dependent services except Psychiatric and Dental; therefore, Computer Printout Data indicates:

Delivery	3,661 Patient Days
Medical	5,137 Patient Days
Surgical	8,790 Patient Days
Less Dental	- 179 Patient Days = $\frac{(240 \text{ Hosp Days} \times 47 \text{ DEPACDU})}{(63 \text{ Total Dental Admissions})}$
Total Patient Days	17,409

DATA FOR PLANNING MODEL:
 ACTUAL AND EXPECTED WORKLOAD
 NAVREGMEDCEN PORTSMOUTH
 1975

<u>PATIENT CATEGORY</u>	<u>DISCHARGES</u> ¹	<u>PATIENT DAYS</u>	
		<u>ACTUAL</u> ¹	<u>EXPECTED</u> ²
Active Duty	7,230	186,415	76,356
Dependents of Active Duty	9,913	45,807	48,253
Retired	2,272	25,984	21,317
Dependents of Retired	2,968	25,535	20,958
All Other	<u>136</u>	<u>1,178</u>	<u>734</u>
TOTAL WORKLOAD	22,159	284,919	167,678

Source: BUMED Code 023, 1 Dec 1976.

¹Information from Naval Medical Data Services Center and Naval School of Health Care Administration, 2 Dec 1976.

²From U.S. National Commission on Professional and Hospital Activities, Professional Activity Study (PAS), on 1 Dec 1976.

POPULATION--PERSONNEL LOADING--PORTSMOUTH HOSPITAL

	<u>1975¹</u>	<u>1981²</u>
Active Duty	88,800	97,914
Dependents of Active Duty	127,237	139,752
Retired Personnel	16,929	17,473
Dependents of Retired, and Deceased	47,683	49,923
Others	<u>31,613</u>	<u>31,796</u>
TOTAL	312,262	336,858

¹From Personnel Loading Plan, Tidewater Area, of 27 February 1975.

²From Personnel Loading Plan, Tidewater Area, of 28 July 1976.

PORTSMOUTH HOSPITAL
OUTPATIENT FACILITIES USED

<u>CLINIC</u>	<u>UNIT¹</u>	<u>1976</u>	<u>MULT. RATIO²</u>	<u>1981 PROJECTED</u>
General Practice	Visits/yr	39,000	336,858 ÷ 324,388	40,499
Dermatology	Visits/yr	21,194	"	22,008
Cardiology	Visits/yr	9,497	"	9,862
ECG	Tests/wk	416	"	431
Chest	Visits/yr	23,478	"	24,381
Inhalation Therapy	Treat./wk	61	"	63
Internal Medicine	Visits/yr	53,473	"	55,529
Gastroenterology	Visits/yr	7,239	"	7,517
Neurology	Visits/yr	5,743	"	5,964
EEG	Tests/wk	38	"	39
Surgery	Visits/yr	21,762	"	22,599
Plastic Surgery	Visits/yr	5,942	"	6,170
Orthopedics	Visits/yr	41,801	"	43,408
OB-Gyn	Visits/yr	48,690	"	50,561
Ophthalmology	Visits/yr	48,833	"	50,710
Otorhinolaryngology	Visits/yr	14,705	"	15,270
Pediatrics	Visits/yr	60,074	"	62,383
Adolescents	Visits/yr	25,746	"	26,736
Psychiatry	Visits/yr	12,219	"	12,689
Urology	Visits/yr	22,731	"	23,605
Pharmacy	Work Units/mo	62,647	"	64,640
Films Exposed	Each/yr	358,090	"	371,855
Radiology	Work Units/yr	358,090	"	371,855
Physical Therapy	Visits/mo	17,274	"	17,938
Occupational Therapy	Visits/mo	15,378	"	15,969
Deliveries	Each/yr	4,352	"	4,519
<u>Additional Info</u>				
Hosp. Admis (1975)	Per Yr	22,159	"	23,011
Central Clinic (1976)	Visits/yr	452,585	"	469,983
ACDU Mil. Pop. (1976)		92,951	"	97,914
Dep. of ACDU Pop. (1976)		132,245	"	139,752
Industrial Pop. ³		0	"	0
Dental Officers ³		17	"	18
<u>(On board Dec 1976)</u>				

¹Unit values required by BUMED computer space plan program to design hospital departmental square footage.

²Per Personnel Loading Plans, Tidewater: of 28 July 1976; 1976 - 324,388 Total Authorized; 1981 - 336,858 Total Authorized Projection, by population serviced.

³Per LT Joe McBride, MSC, USN (BUMED Code 612A), 6 Dec 1976.

PORTSMOUTH HOSPITAL

FY 1976¹

MEALS DATA²

1. Rations Per Day: Average peak meals - 900

984	Rations (All Meals)	(27 Jan 1976)
946	" "	(26 Feb 1976)
940	" "	(29 Jan 1976)
921	" "	(21 Jan 1976)
917	" "	(7 Jun 1976)
917	" "	(24 Aug 1976)
899	" "	(17 Mar 1976)
898	" "	(13 Jul 1976)
894	" "	(12 May 1976)
890	" "	(28 Apr 1976)
871	" "	(8 Sep 1976)
866	" "	(29 Sep 1976)

2. Dining Room and Cafeteria (noon meal only): Peak Meals - 881

881	13 Oct 1971
771	14 Jun 1976
712	14 Jan 1976
706	20 Jan 1976
703	15 Sep 1976
695	13 Sep 1976
683	13 Jan 1976
683	26 Feb 1976
678	3 Aug 1976
678	22 Jul 1976
670	25 Feb 1976
668	12 Apr 1976

3. Patient Trays (All meals in day): Average Peak Meals - 440

460	13 Jul 1976 - Supper
460	28 Jun 1976 - Supper
459	9 Mar 1976 - Supper
459	6 Feb 1976 - Dinner
455	19 May 1976 - Supper
452	29 Sep 1976 - Supper
443	22 Mar 1976 - Supper
430	14 Jan 1976 - Supper
427	20 May 1976 - Dinner
427	31 Aug 1976 - Supper

¹Unit values required by BUMED computer space planning program - to derive hospital departmental square footage.

²Source: FONECON of 7 Dec 1976 with Mrs. Mathews in office of LCDR Chegash, MSC, USN, NAVREGMEDCEN PTSMH VA (804-397-6541 x831).

BREAKDOWN OF ACUTE BEDS - 1981¹

<u>Acute</u>		<u>Proposed</u>	<u>In Computer</u>
Medical/Surgical	Beds (eight 40-bed units)	320 ²	320
Pediatrics	"	50	50
Psychiatric	"	100	100
Obstetrics	"	72	72
ICU	"	30	30
CCU	"	10	10
Cardiothoracic	"	12	12
		<u>594</u>	<u>594</u>
<u>Light Care</u>			
Five 50-bed units (for computer purposes)		223	250 ³
Alcoholic Rehabilitation Unit (Common size unit)		<u>15</u>	<u>15</u>
		832	859 ³

¹Calculation of 6 Dec 1976 by L. Hayet, LCDR, USNR, indicates 582 required.

²With 582 beds calculated, this is projected bed breakdown per Mr. Jim Brassfield, BUMED Architect, on 8 Dec 1976.

a. Intensive Care: Maximum of 10% of Acute Care Beds = 58 beds maximum.

b. Medical/Surgical Nursing: Approximately 50% of acute beds to be medical/surgical nursing @ 40-bed units.

³To be reduced to 832 by one of the 50-bed (light care) units being reduced to 223.

HISTORY
PORTSMOUTH HOSPITAL

A. 7 March 1974 Master Plan 1,045 Beds to 1977
Existing Sq.Ft. (alteration) = 497,500 SF
Addition 240,939 SF
Total Sq.Ft. 738,439 SF

B. 1 March 1975 BFRL 1,040 Beds to 1980
Total Sq.Ft. 724,655 SF

C. 9 December 1976 L. Hayet Modification Per GAO ± 832 Beds to 1981
Existing Sq.Ft. = 497,500 SF
Addition = 402,711 SF
Total 900,211 SF*

* Per first run of computer space program.

PORTSMOUTH HOSPITAL 1981

TRAINING FACILITIES

500 students; 100 staff¹

Reference P-80²

171-10: Academic Instruction Building

Assume:

Classroom size: @ 30 seats per classroom = 630 SF/classroom

$\frac{500 \text{ students}}{30 \text{ seats}} = 16.6$	17 classrooms
--	---------------

Add for scheduling @	$\frac{3 \text{ classrooms}}{20 \text{ classrooms total}}$
----------------------	--

Multiply 20 classrooms x 630 SF = 12,600 SF

Planning Factor = 2.25 x 12,600 = 28,350 SF total

Space Plan Estimate (Bldg. 120' x 70' +)

1st Floor	8,400 SF	Admin & services
2nd Floor	8,400 SF	10 classrooms
3rd Floor	8,400 SF	10 classrooms
(Mechanical)	3,150 SF	
	<u>28,350 SF</u>	

Plus parking, EM Quarters, Exchange Facilities, recreation facilities, etc.

¹Size of training needs per Admiral Cox info to LCDR L. Nichols, week of 1 Dec 1976.

²P-80, pg 170-6, Change 2, May 1975.

FACT SHEET

EXISTING PORTSMOUTH HOSPITAL

REUSE - SAME SITE

PRO

1. Reuse traditional site.
2. Less costly - much less.
3. No problem with present hospital building re-utilization.

CON

1. Only 114 acres.
2. Old utilities, etc.
3. Old building - requires compromises in functional criteria.
4. Not in population center.
5. With construction, medical services in existing hospital a problem.
6. Construction & Design:
 - a. Lower slab-to-slab heights.
 - b. Lower utilization of existing configuration.
 - c. Less energy conservation.

TOTAL	0 FT		547,528
ADD MATERIAL	(10.00%)		54,753
SUBTOTAL			602,281
ADD CIRCULATION	(34.00%)		204,776
SUBTOTAL			807,057
ADD WALLS & PARTITIONS	(09.53%)		76,913
SUBTOTAL			883,970
ADD COVERED ENTRANCE	(01.00%)		8,840
SUBTOTAL			892,810
ADD AMBULANCES	(2 VEH)	700	
SUBTOTAL			893,510
ADD FLEXIBILITY FACTOR	(00.75%)		6,701
TOTAL GROSS SQ FT			900,211

GROSS/NET = 1.64
NORMAL-FWD

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
260	SEATING-AREA-DS	1	140	140	10	ST
261	CLOTHING-ALCOVE-DS	1	5	5	0	
231	MALE-PATIENT-TOILT	1	75	75	3	PX
232	FEMALE-PATIENT-TOILT	1	50	50	2	PX
TOTAL				270		

DPT CONTROL-RECORDS-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
262	CONTROL-AREA-DS	1	115	115	0	
263	RECORDS-STORAGE-DS	1	0	0	0	
TOTAL				115		

DPT ADMINISTRATION-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
117	CO-SDO-DIR-OFFICE	1	150	150	0	
31	TOILET-EXEC	1	30	30	2	PX
233	SECRETARY-WAITING	1	120	120	0	
234	XO-OFFICE	1	150	150	0	
327	DEP-DIR-OFFICE	1	150	150	0	
27	OFFICE-ADMIN-OFFCR-D	1	110	110	1	PR
264	ADMIN-CLERK-DS	1	0	0	0	PR
235	PERSONNEL-CLERK	0	85	0	1	PR
119	CHIEF-MAA	1	110	110	1	PR
236	SENIOR-ENLISTED-ADVR	0	110	0	1	PR
237	SUPPLY-FISCAL-OFFICE	1	110	110	1	PR
328	SUPPLY-CLERK	1	85	85	0	
238	TRNG-CAREER-COUNSEL	0	110	0	1	PR
265	CONF-RM-LIB-DS	1	240	240	0	
239	AUDIO-VISUAL	1	125	125	0	
TOTAL				1,380		

DPT ORAL-DIAGNOSIS-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
106	STD-DENTAL-DOR	2	115	230	0	
266	X-RAY-EXPOSURE-DS	0	115	0	0	
226	X-RAY-PANORAMIC	0	36	0	0	
267	X-RAY-DEVELOPING-DS	0	60	0	0	
268	AUTO-PROCESSOR-DS	0	15	0	0	
120	DEPARTMENT-CHIEF	0	115	0	1	PR
TOTAL				230		

DPT PREV E-DENT-DS

240	DEPT-CHIEF	1	230	230	0
269		2	115	230	0
120	DEPARTMENT-CHIEF	0	115	0	1 PR
	TOTAL			690	

DPT RESTORATIVE-DENT-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
272	GEN-DOR-RESTOR-DS	2	115	230	0	
273	RADIAL-MODULE-DS	0	1810	0	8	DR
120	DEPARTMENT-CHIEF	0	115	0	1	PR
	TOTAL			230		

DPT ORAL-SURGERY-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
107	SURGERY-DOR-HVE	1	115	115	0	
274	GEN-DOR-HVE-SURG-DS	0	115	0	0	
129	SCRUB-ALCOVE	1	80	80	0	
130	RECOVERY-ROOM	1	115	115	0	
83	TOILET-SHOWER-LAV	1	45	45	3	FX
120	DEPARTMENT-CHIEF	0	115	0	1	PR
	TOTAL			355		

DPT PERIODONTIA-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
275	PERIO-DOR-HVE-DS	0	115	0	0	
120	DEPARTMENT-CHIEF	0	115	0	1	PR
	TOTAL			0		

DPT ENDODONTIA-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
276	ENDO-DOR-HVE-DS	0	115	0	0	
120	DEPARTMENT-CHIEF	0	115	0	1	PR
	TOTAL			0		

DPT PROSTHODONTIA-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
277	PROSTHETIC-DOR-DS	0	115	0	0	
243	PROS-BULK-STORAGE	1	0	0	0	
122	LAB-BASE-REQ	1	400	400	0	
278	LAB-BENCHES-DS	1	0	0	0	PR
123	LAB-COBLT-CAST	1	80	80	0	
245	LAB-DING-ROOM	1	80	80	0	
246	LAB-CROWN-AND-BRIDGE	1	120	120	0	
124	LAB-CERAMICS-ROOM	1	80	80	0	

0 115 760
TOTAL 760

DPT C. JLT-OFFICE-DS *****

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
279	OFFICE-CONSULT-DS	1	115	115	1	PR
TOTAL				115		

DPT CENTRAL-STERIL-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
142	INSTRMNT-SCRUB-PREP	1	50	50	0	
200	STERILIZATION-DS	1	115	115	0	
144	RECESSED-STERILIZERS	1	120	120	3	EA
TOTAL				285		

DPT SUPPORT-ELEMENTS-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
281	DENT-SUPPLY-STORE-DS	1	115	115	0	
131	REPAIR-ROOM	1	180	180	0	
126	LINEN-ROOM	1	80	80	0	
282	HOUSEKEEP-SUPPLY-DS	1	50	50	0	
15	JANITOR-CLOSET	1	40	40	0	
250	DUTY-ROOM	1	115	115	0	
83	TOILET-SHOWER-LAV	1	45	45	3	FX
132	STAFF-LKR-OFFICER	1	120	120	12	LK
283	STAFF-LKR-EM-DS	1	40	40	4	LK
347	STAFF-LKR-FM-DS	1	10	10	1	LK
251	STAFF-TOILET-OFFICER	1	200	200	8	FX
284	STAFF-TOILET-EM-DS	1	100	100	4	FX
348	STAFF-TOILET-FM-DS	1	50	50	2	FX
135	LOUNGE-OFFICER	1	195	195	0	
285	LOUNGE-FM-DS	1	115	115	0	
349	LOUNGE-FM-DS	1	115	115	0	
286	CENTRAL-EVAC-EQUP-DS	1	50	50	0	
TOTAL				1,620		

DPT SPECIAL-REQ-DS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
111	TRAINING-DOR	0	115	0	0	
112	TEACHING-DOR	0	115	0	0	
TOTAL				0		

DPT ADMINISTRATION-H

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
-----	------	----	------	---------	-----	----

351	CO-WAIT-RM	1	280	280	2	PR
352	CO	1	400	400	0	
353	CO	1	200	200	1	PR
354	DPT CO-OFFICE	1	30	30	2	FX
355	DPTY-CO-TOILET	1	110	110	1	PR
356	DPTY-CO-SECY-OFFICE	1	200	200	1	PR
357	EXEC-OFFICER-OFF	1	30	30	2	FX
358	EXEC-OFF-TOILET	1	110	110	1	PR
359	EXEC-OFF-SECY-OFF	1	320	320	4	PR
360	ADM-ASST-OFFICE	1	200	200	1	PR
361	ADM-OFFICER-OFFICE	1	30	30	2	FX
362	ADM-OFF-TOILET	1	110	110	1	PR
363	ADM-OFF-SECY-WAIT-RM	1	480	480	6	PR
364	ADM-OFF-CLERKS-OFF	1	200	200	1	PR
365	CH-NURSE-OFFICE	1	30	30	2	FX
366	CH-NURSE-TOILET	1	140	140	1	PR
367	CH-NURSE-ASST-OFF	1	140	140	1	PR
368	CH-NURSE-SECY-WAIT	1	110	110	1	PR
369	CH-NURSE-EDUC-COORD	1	110	110	1	PR
370	CH-NURSE-ANEST-INSTR	1	110	110	1	PR
371	CH-NURSE-OR-INSTR	1	160	160	2	PR
372	CH-NURSE-ENLSTD-TRNG	1	300	300	0	
373	CH-NURSE-CONF-RM	1	140	140	1	PR
374	PLAN-PROJ-ASSISTANT	1	160	160	2	PR
375	PLAN-PROJ-STAFF	1	140	140	1	PR
376	PAT-APP-OFFICER-OFF	1	110	110	1	PR
377	PAT-APP-CLERICAL	1	140	140	0	
378	PAT-APP-DECEDENT-CNS	1	320	320	4	PR
379	PAT-APP-REGISTRAT-BR	1	400	400	5	PR
380	MED-REC-BRANCH	1	640	640	8	PR
381	MED-REC-TRANS-I	1	110	110	1	PR
382	MED-REC-TRANS-SUPV	1	160	160	2	PR
383	MED-RECORDS	1	2658	2,658	0	
384	MED-REC-STORAGE	1	300	300	0	
385	MED-REC-DRS-WKRN	1	582	582	0	
386	BAG-ROOM	1	330	330	3	PR
387	MIL-LIAISON-OFFICES	1	400	400	5	PR
388	MIL-LIAISON-CLERKS	1	140	140	1	PR
389	GEN-SVCS-DIRECTOR	1	320	320	4	PR
390	GEN-SVCS-OFFICE	1	600	600	0	
391	GEN-SVCS-CEN-FILES	1	140	140	1	PR
392	LEGAL-OFFICE	1	160	160	2	PR
393	LEGAL-OFFICE-CLERKS	1	140	140	1	PR
394	PERS-OFFICER	1	110	110	1	PR
395	PERS-OFFICER-SECY	1	400	400	5	PR
396	PERS-MILITARY-BRANCH	1	400	400	5	PR
397	PERS-CIVILIAN-BRANCH	1	140	140	1	PR
398	TRNG-BRANCH-OFFICER	1	200	200	0	
399	TRNG-AIDS-SUPP-EQUIP	1	200	200	0	
TOTAL			13,470			

DPT ADMINISTRATION-H

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
400	BRANCH-CLERKS	1	160	160	2	PR
401	BRSE-DIV-OFFICE	1	160	160	2	PR
402	OPS-SVCS-CHIEF	1	140	140	1	PR
		1	240	240	3	PR

399	CS-DUPL-EQUIP	1	1000	1,000	0	
400	ICE	1	160	160	2	PR
401	MACHINE-ROOM	1	800	800	0	
402	SPEC-SVCS-OFFICER	1	140	140	1	PR
410	SPEC-SVCS-CLERKS	1	160	160	2	PR
411	STAFF-TOILETS-MALE	1	125	125	5	FX
412	STAFF-TOILETS-FEMALE	1	300	300	12	FX
413	FISCAL-SUPPLY-CHIEF	1	110	110	1	PR
414	FISCAL-BR-HEAD	1	80	80	1	PR
415	FISCAL-SUPV-BJT-ANAL	1	80	80	1	PR
416	FISCAL-AGT-CASHIER	1	240	240	3	PR
417	FISCAL-WRK-SUPV	1	80	80	1	PR
418	FISCAL-WRK-PAY-CLKS	1	80	80	1	PR
419	FISCAL-WRK-ACC-CLKS	1	240	240	3	PR
420	SUPPLY-BR-HEAD	1	110	110	1	PR
421	SUPPLY-IMPR-FND-CSHR	1	140	140	1	PR
422	SUPPLY-WORK-STA-SUPV	1	80	80	1	PR
423	SUPPLY-WORK-STA-CLKS	1	480	480	6	PR
15	JANITOR-CLOSET	4	40	160	0	
	TOTAL			6,205		

DPT MAIN-LOBBY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
424	MAIN-LOBBY	1	1164	1,164	0	
425	INFORMATION	1	160	160	2	PR
426	OD-OFFICE	1	160	160	2	PR
427	PUBLIC-TOILETS-MALE	1	125	125	5	FX
428	PUBLIC-TOILETS-FEM	1	100	100	4	FX
	TOTAL			1,709		

DPT POST-OFFICE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
429	PUBLIC-AREA	1	140	140	0	
430	US-POSTAL-WORK-AREA	1	200	200	0	
431	US-POSTAL-REC-ROOE	1	110	110	0	
432	HOSP-MAIL-POST-BOXES	1	400	400	0	
433	MESSAGE-CENTER	1	110	110	0	
	TOTAL			960		

DPT MEDICAL-LIBRARY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
434	LIBRARIAN-OFFICE	1	140	140	1	PR
435	READING-RM-SEATING	1	240	240	0	
436	CHANGING-DESK	1	200	200	0	
437	WORKROOM	1	200	200	0	
438	STACK-AREA	1	400	400	0	
	TOTAL			1,180		

DPT PATL.-LIBRARY

438	IG-RM-SEATING	1	250	250	10	RD
440	TRAINING-ROOM	1	180	180	0	
441	WORKROOM	1	140	140	0	
442	STACK-AREA	1	300	300	0	
443	BOOK-CARTS	1	110	110	0	
	TOTAL			980		

DPT GEN-CONFERENCE-ROOMS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
444	CONFERENCE-ROOM	1	690	690	0	
445	TRAINING-ROOM	1	320	320	0	
	TOTAL			1,010		

DPT EDUCATION-TRAINING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
446	DIR-PROF-EDUCATION	1	200	200	1	PR
447	DIR-PROF-EDUC-SECY	1	110	110	1	PR
448	DIR-PROF-EDUC-TOILET	1	30	30	2	FX
	TOTAL			340		

DPT ADMITTING-DISPOSITN

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
449	ADMISSION-WAITING	1	420	420	30	ST
450	ADMIT-RECORD-OFF	1	320	320	4	PR
451	ADMIT-OFF-CUBICLES	3	60	180	0	
452	COLLECTION-AGENT	1	280	280	2	PR
453	ADDRESSOGRAPH-MACH	1	80	80	1	PR
454	PATIENT-TOILETS	1	30	30	2	FX
455	STRETCHER-WUCHR-STOR	1	60	60	0	
	TOTAL			1,370		

DPT OUTPATIENT-SERVICE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
456	CEN-CLINIC-RECEPTION	1	742	742	53	ST
457	CEN-APPOINTMENTS-OFF	1	720	720	12	PR
458	OUTPAT-RECORDS-STOR	1	3090	3,090	0	
459	OUTPAT-REC-CLERKS	1	180	180	3	PR
460	ADDRESSOGRAPH-MACH	1	80	80	1	PR
461	OPD-ADM-ASSISTANT	1	110	110	1	PR
462	OPD-SECY-WAITING	1	110	110	1	PR
463	NURSES-OFFICE	1	110	110	1	PR
464	TRANSCRIBING	1	240	240	6	PR
465	PA T-TOILET-MALE	1	125	125	5	FX
466	PA T-TOILET-FEM	1	150	150	6	FX
467	OPD OFFICE-CHIEF	1	140	140	1	PR
468	OPD-CHIEF-EXAM-ROOM	1	110	110	0	

DPT GEN PRACTICE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
471	WAIT-RM-CLINIC-IMN	1	42	42	3	ST
472	PATIENT-TOILETS-MALE	1	0	0	0	FX
473	PATIENT-TOILETS-FEM	1	0	0	0	FX
474	CONTROL-RECEPTION	1	110	110	0	
475	NURSES-STATION	1	110	110	1	PR
476	DOCTORS-OFFICES	17	110	1,870	1	PR
477	EXAMINING-ROOMS	0	110	0	0	
478	TREATMENT-ROOM	1	200	200	0	
479	IMMUNIZATION-ROOM	1	140	140	0	
480	NUTRITION-CONSULT-RM	1	110	110	0	
481	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL				2,882		

DPT DERMATOLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
487	WAITING-ROOM	1	322	322	23	ST
488	PATIENT-TOILETS-MALE	1	50	50	2	FX
489	PATIENT-TOILETS-FEM	1	50	50	2	FX
490	CONTROL-RECEPTION	1	110	110	0	
475	NURSES-STATION	1	110	110	1	PR
491	DOCTORS-OFFICES	4	110	440	1	PR
492	EXAMINING-ROOM	8	110	880	0	
495	TREATMENT-ROOM	1	200	200	0	
496	ULTRAVIOLET-BOOTH	1	40	40	0	
497	DERMATOL-PROCED-RM	1	140	140	0	
498	DERMATOL-LAB	1	60	60	0	
11	CLEAN-STORAGE	1	110	110	0	
12	SOILED-STORAGE	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
481	STAFF-LOUNGE-CONF-RM	1	200	200	0	
484	DERMATOLOGY-CHIEF	1	140	140	1	PR
485	EXAMINING-ROOM	1	110	110	0	
486	SECY-WAITING-RM	1	110	110	1	PR
TOTAL				3,222		

DPT CARDIOLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
532	WAITING-ROOM	1	252	252	18	ST
533	PATIENT-TOILETS-MALE	1	50	50	2	FX
534	PATIENT-TOILETS-FEM	1	50	50	2	FX
535	CONTROL-RECEPTION	1	110	110	0	
536	NURSE OFFICE	1	110	110	0	
537	DOCTORS-OFFICES	4	110	440	1	PR

TESTING-AREA	1	550	550	5 SN
WORK-AREA	1	550	550	5 SP
ECG-DRESS-CUBICLES	1	100	100	5 CB
543 GRAPH-LAB-PH-ECHOCAR	1	300	300	0
544 TREADMILL	1	140	140	0
545 TECHNUS-OFFICE-AREA	1	480	480	6 PR
546 ECG-VECTOR-TAPE-STOR	1	600	600	0
547 LITTER-WHCHR-STOR	1	80	80	0
548 EQUIP-SUPPLY-STOR	1	140	140	0
499 CLEAN-STORAGE	1	110	110	0
500 UTIL-SOILED-STOR	1	110	110	0
501 STAFF-LOUNGE-CONF-RH	1	200	200	0
482 STAFF-TOILET-MALE	1	30	30	2 FX
483 STAFF-TOILET-FEMALE	1	30	30	2 FX
15 JANITOR-CLOSET	1	40	40	0
529 CARDIOLOGY-CHIEF	1	140	140	1 PR
530 EXAMINING-ROOM	1	110	110	0
531 SECY-WAITING	1	110	110	1 PR
TOTAL			5,692	

DPT CHEST-INFECTIOUS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
555	WAITING-ROOM	1	980	980	70	ST
556	PATIENT-TOILETS-MALE	1	125	125	5	FX
557	PATIENT-TOILETS-FEM	1	100	100	4	FX
558	CONTROL-RECEPTION	1	110	110	0	
559	NURSES-OFFICE	1	110	110	1	PR
560	DOCTORS-OFFICES	17	110	1,870	1	PR
561	EXAMINING-ROOMS	26	110	2,860	0	
562	TREATMENT-ROOMS	1	200	200	0	
563	INHAL-THERAPY-CHIEF	1	110	110	1	PR
564	MEDICATION-STATION	1	110	110	0	
565	EQUIP-PREP	1	200	200	0	
566	GAS-CYLINDER-STOR	1	30	30	0	
567	INHAL-THERAPY-CUBICS	1	80	80	1	CB
568	INHAL-THERAPY-TRTMT	1	80	80	1	TB
569	PULMON-FUNCTION-LAB	1	400	400	0	
570	TREADMILL-ROOM	1	140	140	0	
571	BRONCHOSPIRO-ROOM	1	300	300	0	
572	TECHNUS-OFFICE	1	400	400	5	PR
519	INFECT-DISEASE-LAB	1	200	200	0	
547	LITTER-WHCHR-STOR	1	80	80	0	
548	EQUIP-SUPPLY-STOR	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RH	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
549	PULMON-DISEASE-CHIEF	1	140	140	1	PR
550	EXAMINING-ROOM	1	110	110	0	
551	SPCY-WAITING	1	110	110	1	PR
508	P-DISEASE-CHIEF	1	140	140	1	PR
509	ING-ROOM	1	110	110	0	
510	SECY-WAITING	1	110	110	1	PR

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
597	WAITING-ROOM	1	1778	1,778	127	ST
598	PATIENT-TOILETS-MALE	1	200	200	8	FX
599	PATIENT-TOILETS-FEM	1	200	200	8	FX
600	CONTROL-RECEPTION	1	110	110	0	
601	NURSES-OFFICE	1	110	110	0	
602	DOCTORS-OFFICE	23	110	2,530	1	PR
603	EXAMINING-ROOMS	46	110	5,060	0	
604	STUDENT-OFFICES	1	110	110	1	PR
605	EXAMINING-ROOMS	2	110	220	0	
606	TREATMENT-ROOM	1	200	200	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
592	INTERNAL-MED-CHIEF	1	140	140	1	PR
593	EXAMINING-ROOM	1	110	110	0	
594	SECY-WAITING	1	110	110	1	PR
595	ADMIN-ASSISTANT	1	110	110	1	PR
596	CONFERENCE-ROOM	1	400	400	0	
TOTAL			11,908			

 DPT GASTROENTEROLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
610	WAITING-ROOM	1	224	224	16	ST
611	PATIENT-TOILETS-MALE	1	50	50	2	FX
612	PATIENT-TOILETS-FEM	1	50	50	2	FX
613	CONTROL-RECEPTION	1	110	110	0	
614	DOCTORS-OFFICES	3	110	330	1	PR
615	EXAMINING-ROOMS	5	110	550	0	
616	TREATMENT-ROOM	1	200	200	0	
617	TECHNICIAN-ROOM	1	110	110	1	PR
618	PROCTOSCOPY-ROOM	1	160	160	0	
619	PREP-ROOM	1	110	110	0	
620	TOILET	1	30	30	2	FX
621	GASTR-AN-CYTO-LAB	1	200	200	0	
622	ENDOSCOPY-ROOM	1	240	240	0	
623	RECOVERY-ROOM	1	100	100	1	BD
624	TOILET	1	30	30	2	FX
625	ESOPH-MANOMETRIC-RM	1	200	200	0	
547	LITTER-WHCHR-STOR	1	80	80	0	
548	EQUIP-SUPPLY-STOR	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANIT-LOSET	1	40	40	0	
607	GASTR-ROL-CHIEF	1	140	140	1	PR
608	EXAMIL-ROOM	1	110	110	0	
609	SECY-WAITING	1	110	110	1	PR

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
629	WAITING-ROOM	1	322	322	23	ST
630	PATIENT-TOILETS-MALE	1	50	50	2	FY
631	PATIENT-TOILETS-FEM	1	50	50	2	FY
632	CONTROL-RECEPTION	1	110	110	0	
633	DOCTORS-OFFICES	4	110	440	1	PR
634	EXAMINING-ROOMS	8	110	880	0	
635	SPEECH-PATH-OFF-EXAM	1	110	110	0	
636	SPEECH-PATH-TEST	1	400	400	0	
637	EEG-TESTING-AREA	1	110	110	1	SN
638	EEG-WORK-AREA	1	110	110	1	SN
639	EEG-INTERPRET-ROOM	1	140	140	0	
640	ECHOENCEPHALOG-RM	1	300	300	0	
641	ELECTRONOGRAM-RM	1	140	140	0	
547	LITTER-WHCHR-STOR	1	80	80	0	
548	EQUIP-SUPPLY-STOR	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FY
483	STAFF-TOILET-FEMALE	1	30	30	2	FY
15	JANITOR-CLOSET	1	40	40	0	
626	NEUROLOGY-CHIEF	1	140	140	1	PR
627	EXAMINING-ROOM	1	110	110	0	
628	SECY-WAITING	1	110	110	1	PR
TOTAL			4,262			

DPT SURGERY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
647	WAITING-ROOM	1	504	504	36	ST
648	PATIENT-TOILETS-MALE	1	75	75	3	FY
649	PATIENT-TOILETS-FEM	1	50	50	2	FY
650	CONTROL-RECEPTION	1	110	110	0	
651	NURSES-OFFICE	1	110	110	0	
654	DOCTORS-OFFICES	6	110	660	1	PR
655	EXAMINING-ROOMS	12	110	1,320	0	
656	MINOR-SUR-TMT-RM	2	200	400	0	
657	ENDOSCOPY-ROOM	1	240	240	0	
658	TOILET	1	30	30	2	FY
659	PROCTOSCOPIC-ROOM	1	160	160	0	
660	PREPARATION-ROOM	1	110	110	0	
661	PATIENT-TOILET	1	30	30	2	FY
662	VASCULAR-DIAGN-LAB	1	200	200	0	
663	RECOVERY-ROOM	1	110	110	0	
664	RECOVERY-TOILET	1	30	30	2	FY
547	LITTER-WHCHR-STOR	1	80	80	0	
548	EQUIP-SUPPLY-STOR	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FY
483	STAFF-TOILET-FEMALE	1	30	30	2	FY

643	EN	NO-ROOM	1	110	110	0
644	SE	TING	1	110	110	1 PR
645	ADMI	ST-OFFICE	1	110	110	1 PR
646		CONFERENCE-ROOM	1	400	400	0
TOTAL					5,749	

DPT PLASTIC-SURGERY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
673	WAITING-ROOM	1	252	252	18	ST
493	PATIENT-TOILET-MALE	1	0	0	0	FX
494	PATIENT-TOILET-FEM	1	50	50	2	FX
678	DOCTORS-OFFICES	3	110	330	1	PR
679	EXAMINING-ROOMS	6	110	660	0	
681	MINOR-OR-TRTMT-RM	1	200	200	0	
682	STORAGE	1	200	200	0	
683	WORKROOM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
674	PLASTIC-SURG-CHIEF	1	140	140	1	PR
675	EXAMINING-ROOM	1	110	110	0	
676	SECY-WAITING	1	110	110	1	PR
677	CONFERENCE-ROOM	1	200	200	0	
TOTAL				2,432		

DPT ORTHOPEDICS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
689	WAITING-ROOM	1	952	952	68	ST
690	PATIENT-TOILETS-MALE	1	125	125	5	FX
691	PATIENT-TOILETS-FEM	1	100	100	4	FX
692	CONTROL-RECEPTION	1	110	110	0	
693	DOCTORS-OFFICES	12	110	1,320	1	PR
694	EXAMINING-ROOMS	24	110	2,640	0	
695	NURSES-STATION	1	110	110	0	
696	PODIATRISTS-OFFICE	1	110	110	1	PR
697	EXAMINING-ROOMS	2	110	220	0	
698	CAST-ROOM	1	400	400	4	TB
699	PLASTER-PREP-STORE	1	80	80	0	
700	SPLINT-CRUTCH-STORE	1	110	110	0	
701	APPL-FIT-RM-ADJUST	1	240	240	3	CB
702	GAIT-OBSERVE-AREA	1	140	140	0	
703	RADIOGRAPH-EXPOSE-RM	1	270	270	0	
704	AUTO-FILM-PROCESS	1	80	80	0	
705	SORTING-AREA	1	80	80	0	
547	LITTER-WECHR-STOR	1	80	80	0	
548	EQUIP-SUPPLY-STOR	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANI CLOSET	1	40	40	0	
684	ORTH CS-CHIEF	1	140	140	1	PR
685	EXAMINING-ROOM	1	110	110	0	
686	CONFERENCE-ROOM	1	200	200	0	

DPT OB-

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
709	WAITING-ROOM	1	1050	1,050	75	ST
710	PATIENT-TOILETS-MALE	1	75	75	3	FX
711	PATIENT-TOILETS-FEM	1	250	250	10	FX
712	CONTROL-RECEPTION	1	110	110	0	
713	DOCTORS-OFFICES	14	110	1,540	0	
714	EXAMINING-ROOMS	28	110	3,080	0	
715	TREATMENT-ROOMS	1	200	200	0	
716	NURSES-STATION	1	110	110	0	
717	WEIGHTS-MEASURES	1	110	110	0	
718	SPECIMEN-TOILETS	1	40	40	2	FX
719	SPECIMEN-COLLECTION	1	80	80	0	
720	PUBL-VIS-AIDS-STOR	1	80	80	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
706	OBSYN-CHIEF-OFFICE	1	140	140	1	PR
707	EXAMINING-ROOM	1	110	110	0	
708	SECY-WAITING	1	110	110	1	PR
TOTAL				7,605		

DPT OPHTHALMOLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
737	WAITING-ROOM	1	1050	1,050	75	ST
738	PATIENT-TOILETS-MALE	1	125	125	5	FX
739	PATIENT-TOILETS-FEM	1	150	150	6	FX
740	CONTROL-RECEPTION	1	110	110	0	
741	OPTICAL-DISPEN-REPRS	1	110	110	0	
742	CNT-LENS-FIT-DISPNS	1	180	180	0	
743	OPTOMETR-OFF-EYE-LN	2	195	390	0	
744	OPHTHALMOLOGIST-OFF	14	110	1,540	1	PR
732	EYE-LANE	28	160	4,480	0	
745	SCREEN-DILATE-AREAS	1	140	140	0	
746	EYE-TREATMENT-ROOM	1	200	200	0	
747	VISUAL-FIELD-ROOMS	1	110	110	0	
748	LENS-MODIFICATION-RM	1	110	110	0	
749	TONOGRAPHY-ROOM	1	110	110	0	
750	ELECTRORETINOGRAPHY	1	180	180	0	
751	LASER-ROOM	1	180	180	0	
752	CRYOTHERAPY-ROOM	1	110	110	0	
753	ANGIOGRAPHY-ROOM	1	110	110	0	
754	CONFERENCE-ROOM	1	400	400	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX

733	OP	1	140	140	1	PR
734	OP	1	140	140	1	PR
735	SEC	1	110	110	1	PR
		TOTAL		10,695		

DPT OTORHINOLARYNGOLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
758	WAITING-ROOM	1	364	364	26	ST
759	PATIENT-TOILETS-MALE	1	0	0	0	PX
760	PATIENT-TOILETS-FEM	1	50	50	2	FX
761	CONTROL-RECEPTION	1	110	110	0	
762	DOCTORS-OFFICES	4	110	440	1	PR
763	EXAMIN-ROOMS-ENT	8	110	880	0	
764	OTOLOGICAL-SURG-ORS	1	200	200	0	
765	RECOVERY-ROOM	1	110	110	0	
766	TOILET	1	30	30	2	FX
767	NURSES-STATION	1	110	110	0	
768	VESTIBULAR-EXAM-RM	1	110	110	0	
769	AUDIOBOOTH-ROOMS	1	220	220	2	SP
770	AUDIOL-OFFICE-EXAM	1	140	140	0	
771	HEAR-AID-FITTING-RM	1	80	80	0	
772	HEAR-AID-LAB	1	110	110	0	
773	AUDIO-CLERK-OFFICE	1	110	110	1	PR
774	AUDIO-RECORD-FILES	1	110	110	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
755	OTORHINOLARYN-CHIEF	1	140	140	1	PR
756	EXAMINING-ROOM	1	110	110	0	
757	SECY-WAITING	1	110	110	1	PR
		TOTAL		4,054		

DPT EMERGENCY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
775	WAITING-ROOM	1	140	140	10	ST
776	PATIENT-TOILETS-MALE	1	0	0	0	PX
777	PATIENT-TOILETS-FEM	1	0	0	0	PX
778	CONTROL-RECEPTION	1	110	110	0	
779	NURSES-OFFICE	1	110	110	0	
780	DOCTORS-OFFICE	1	110	110	1	PR
781	EXAMINING-ROOM	2	110	220	0	
782	FAMILY-WAIT-CONSLT	1	110	110	0	
783	AMBULANCE-DISPATCH	1	110	110	0	
784	CORPSMEN-BEDROOM	1	600	600	6	PR
785	TOILET-SHOWER	1	45	45	3	FX
786	TREATMENT-ROOM	1	200	200	0	
787	EMERGENCY-ROOM	1	300	300	0	
788	TREATMENT-CUBICLES	1	650	650	5	SN
789	NURSES-STATION	1	110	110	0	
790	MOOD-BEDROOM	1	110	110	1	PR
791	TOILET-SHOWER	1	45	45	3	FX

793	TOILET-ROOM	1	40	40	0	FX
547	LITTE	1	80	80	0	
548	EQUIP	1	140	140	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL				3,865		

DPT PHYSICAL-EXAMINATION

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
794	WAITING-ROOM	1	280	280	20	ST
795	RECEPTION-DESK	1	110	110	0	
796	HISTORY-EXAMINATION	1	280	280	0	
797	GENERAL-OFFICE	1	280	280	0	
798	ADMINISTRATION-OFF	1	110	110	0	
799	LABORATORY	1	280	280	0	
800	CHEST-XRAY	1	140	140	0	
801	CHEST-XRAY-DARK-RM	1	60	60	0	
802	SPECIMEN-TOILET-MALE	1	40	40	2	FX
803	SPECIMEN-TOILET-FEM	1	40	40	2	FX
804	DRESSING-BOOTH-MALE	10	20	200	0	
805	DRESSING-BOOTH-FEM	10	20	200	0	
806	INTERIOR-TOILET-MALE	1	60	60	4	FX
807	TOILET-MALE	1	30	30	2	FX
808	INTERIOR-WAIT-FEM	1	60	60	0	
809	INTERIOR-TOILET-FEM	1	30	30	2	FX
810	AUDIO-EXAMINATION	2	110	220	0	
811	CORE-MED-EXAM-RMS	6	110	660	0	
812	CORE-CENTER	1	200	200	0	
813	CORE-STOR-LOCKERS	6	30	180	0	
814	INTERIOR-WAITING	1	110	110	0	
815	DOCTOR-OFF-EXAM-RMS	2	140	280	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL				4,370		

DPT PEDIATRICS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
820	PLAY-AREA	1	110	110	0	
821	WAIT-CLINIC-IMMUNIZ	1	868	868	62	ST
822	PATIENT-TOILETS-MALE	1	125	125	5	FX
823	PAT-TOILET-FEM-DIAP	1	150	150	4	FX
824	CONTROL-RECEPTION	1	110	110	0	
825	DOCTORS-OFFICES	11	110	1,210	1	PR
826	EXAMINING-ROOMS	22	110	2,420	0	
827	TREATMENT-ROOMS	1	200	200	0	
828	NURSES-STATION	1	110	110	0	

830	IMMU	ION-ROOM	1	140	140	0
831	ISO	-WAITING	1	110	110	0
832	ISO	N-TOILET	1	30	30	2 FX
833	ISOLA	ION-EXAM-ROOM	1	110	110	0
499	CLEAN	-STORAGE	1	110	110	0
500	UTIL	-SOILED-STOR	1	110	110	0
501	STAFF	-LOUNGE-CONF-RM	1	200	200	0
482	STAFF	-TOILET-MALE	1	30	30	2 FX
483	STAFF	-TOILET-FEMALE	1	30	30	2 FX
15	JANITOR	-CLOSET	1	40	40	0
816	PEDIATRICS	-CHIEF-OFF	1	140	140	1 PR
817	EXAMINING	-ROOM	1	110	110	0
818	SECY	-WAITING	1	110	110	1 PR
819	ADMIN	-ASSISTANT	1	110	110	1 PR

TOTAL 6,793

DPT ADOLESCENT

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
834	WAITING-ROOM	1	840	840	60	ST
835	PATIENT-TOILETS-MALE	1	125	125	5	FX
836	PATIENT-TOILETS-FEM	1	100	100	4	FX
837	CONTROL-RECEPTION	1	110	110	0	
838	NURSES-OFFICE	1	110	110	0	
839	DOCTORS-OFFICES	11	110	1,210	1	PR
840	EXAMINING-ROOMS	22	110	2,420	0	
841	TREATMENT-ROOMS	1	200	200	0	
842	WTS-MEASURES-NUTRN	1	110	110	0	
843	SOCIAL-WORKER-OFF	1	110	110	1	PR
844	PSYCHOLOGIST-OFFICE	1	140	140	1	PR
845	PSYCHIATRIST-OFFICE	1	140	140	1	PR
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL				6,135		

DPT PSYCHIATRY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
849	WAITING-ROOM	1	406	406	29	ST
850	PATIENT-TOILETS-MALE	1	50	50	2	FX
851	PATIENT-TOILETS-FEM	1	50	50	2	FX
852	CONTROL-RECEPTION	1	110	110	0	
853	PSYCHOLOGIST-OF-EXAM	0	180	0	0	
854	SOCIAL-WORKER-OFF	1	140	140	0	
856	TEST-TREATMT-RMS	1	140	140	0	
857	CONF-GROUP-MEET-RM	1	480	480	0	
858	OBSERVATION-ROOMS	1	110	110	0	
859	SECY-CLERICAL-OFF	1	480	480	0	
860	LIBRARY-TEST-FILES	1	240	240	0	
861	PSYCHIATRIST-OFF-EXM	10	180	1,800	0	
862	CHILD-PSYCH-OFFICE	1	180	180	0	
863	CHILD-PSYC-MIRROR-RM	1	110	110	0	

548	EQUIP-	PLY-STOR	1	140	140	0
482	STAF	ET-MALE	1	30	30	2 FX
463	STA	ET-FEMALE	1	30	30	2 FX
15	JANL	-CLOSET	1	40	40	0
846	PSYCHIATRY-CH-EXAM		1	200	200	1 PR
847	SECY-WAITING		1	110	110	1 PR
848	ADMIN-ASSISTANT		1	110	110	1 PR
TOTAL				5,096		

DPT UROLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
868	WAITING-ROOM	1	364	364	26	ST
869	PATIENT-TOILETS-MALE	1	50	50	2	FX
870	PATIENT-TOILETS-FEH	1	50	50	2	FX
871	CONTROL-RECEPTION	1	110	110	0	
872	NURSES-OFFICE	1	110	110	0	
875	DOCTORS-OFFICES	6	110	660	1	PR
876	EXAMINING-ROOMS	9	110	990	0	
877	CYSTOSCOPY-RMS-XRAY	2	260	520	0	
878	CYSTO-DRESS-CUBICLES	1	80	80	2	CB
879	CYSTO-TOILETS	2	40	80	2	FX
880	CYSTO-RECOVERY-RM	1	220	220	2	BD
881	CYSTO-REC-RM-TOILET	1	40	40	2	FX
882	SPEC-SURG-RMS	1	300	300	0	
883	PREP-ROOM	1	110	110	0	
884	DRESS-CUBICLES	1	40	40	1	CB
885	TOILETS	1	40	40	2	FX
886	UROLOGY-LAB	1	200	200	0	
887	UROLOGY-WORKROOM	1	200	200	0	
888	INSTRUCTORS-OFFICE	1	110	110	0	
889	FILE-STORAGE	1	200	200	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
501	STAFF-LOUNGE-CONF-RM	1	200	200	0	
482	STAFF-TOILET-MALE	1	30	30	2	FX
483	STAFF-TOILET-FEMALE	1	30	30	2	FX
15	JANITOR-CLOSET	1	40	40	0	
865	UROLOGY-CHIEF-OFFICE	1	140	140	1	PR
866	EXAMINING-ROOM	1	110	110	0	
867	SECY-WAITING	1	110	110	1	PR
TOTAL				5,354		

DPT PHARMACY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
16	PHARMACY-WAITING	1	854	854	61	ST
891	DRUG-INFO-CENTER	1	200	200	0	
892	PHARMACY-CHIEF	1	140	140	1	PR
893	SECRETARY	1	110	110	1	PR
894	OFFICE-AREAS	1	240	240	0	
895	CLER-PERS-OFFICE	1	160	160	2	PR
896	DP-KEYPUNCH	1	110	110	0	
23	WK-AREA-BULK-CMPD	1	110	110	0	
18	WK-AREA-SPEC-PREP	1	300	300	0	
899	WORK-AREA-UNIT-DOSE	1	1000	1,000	0	

22	W	A-BULK-STORAGE	1	1600	1,600	0
903	W	EA-HOSP-ISSUE	1	200	200	0
904	PH	TECH-WATCHRM	1	110	110	1 PR
905	PHARM	TECH-TOILET	1	45	45	3 FX
906		SECURE-STORAGE	1	200	200	0
907		FLAMABLE-STORAGE	1	110	110	0
15		JANITOR-CLOSET	1	40	40	0
TOTAL				6,369		

DPT LAB-ADMINISTRATION

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
952	CP-RECS-WAIT-RECEPT	1	560	560	40	FX
953	CP-RECS-PAT-TOILT-M	1	175	175	7	FX
954	CP-RECS-PAT-TOILT-F	1	150	150	6	FX
955	CP-RECS-SPECMN-RECVV	1	200	200	0	
956	CP-RECS-BLOOD-DRAW	1	400	400	4	SN
957	CP-RECS-CENTRAL-RECS	1	600	600	0	
958	CP-RECS-COMPTR-PROCC	1	600	600	0	
959	CP-RECS-ACCESSIONING	1	110	110	0	
960	CP-RECS-STAT-LAB	1	640	640	0	
961	CP-RECS-MAIL-ROOM	1	110	110	0	
962	CP-ADM-LAB-SVC-CHIEF	1	350	350	0	
963	CP-ADM-RESIDENTS-OFF	1	80	80	1	PR
964	CP-ADM-SECY-WAIT	1	230	230	2	PR
965	CP-ADM-OFFICES	1	220	220	2	PR
966	CP-ADM-CONF-RM	1	400	400	0	
967	CP-ADM-LIBR-AUD-VIS	1	110	110	0	
968	CP-ADM-TECHN-TRAIN	1	400	400	0	
969	CP-ADM-STUDENT-LAB	1	480	480	0	
970	CP-ADM-RSH-DEV-LAB	1	480	480	0	
971	CP-ADM-CENTRAL-STOR	1	600	600	0	
972	CP-ADM-EQUIP-REPAIR	1	250	250	0	
973	CP-ADM-CREW-LOUNGE	1	900	900	0	
974	CP-ADM-CREW-TOILT-MM	1	150	150	6	FX
975	CP-ADM-CREW-TOILT-F	1	100	100	6	FX
TOTAL			8,295			

DPT LAB-ANATOMICAL

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
908	MORGUE-BODY-STOR	1	140	140	0	
909	MORGUE-CADAVER-STORR	1	60	60	0	
910	MORGUE-VIEW-PREP	1	200	200	0	
911	MORGUE-DISECTION	1	400	400	2	TB
912	MORGUE-AUTOPSY	1	400	400	2	TB
913	MORGUE-CONF-AREA	1	420	420	30	ST
914	MORGUE-SHR-TOILT-LKR	1	170	170	3	FX
915	MORGUE-GROSS-PHOTO	1	110	110	0	
916	MORGUE-SPECMN-STOR	1	140	140	0	
917	MORGUE-LAB	1	140	140	0	
918	MORGUE-OFFICE	1	110	110	1	PR
919	SUR-PTH-SPECMN-ACCES	1	140	140	0	
920	SUR-PTH-SPECMN-REC	1	200	200	0	
921	SUR-PTH-FROZEN-SECT	1	60	60	0	

923	S	H-TISSUE-PROC	1	200	200	0
924	S	H-STAINING	1	200	200	0
925	S	H-MOUNTING	1	200	200	0
926		SUR-PTH-SPEC-STAIN	1	240	240	0
927		SUR-PTH-RTN-MICROSCY	1	110	110	0
928		SUR-PTH-FLUOR-MICRO	1	110	110	0
929		SUR-PTH-SLIDE-STOR	1	500	500	0
930		SUR-PTH-BLOCKS-STOR	1	500	500	0
931		SUR-PTH-STUDY-SETS	1	110	110	0
932		SUR-PTH-MUSEUM	1	200	200	0
933		SUR-PTH-GROSS-PHOTO	1	110	110	0
934		SUR-PTH-MICRO-PHOTO	1	110	110	0
935		SUR-PTH-OFFICE-AREA	1	550	550	5 PR
936		SUR-PTH-SECY-SUPPT	1	400	400	5 PR
937		SUR-PTH-TEACHING	1	110	110	2 PR
938		CYTOPATH-ACCESSION	1	140	140	0
939		CYTOPATH-STAINING	1	110	110	0
940		CYTOPATH-FLUID-PREP	1	110	110	0
941		CYTOPATH-COVERSLIPNG	1	70	70	0
942		CYTOPATH-SLIDE-FILES	1	70	70	0
943		CYTOPATH-MICROSCOPY	1	200	200	0
944		CYTOPATH-OFFICE-AREA	1	220	220	2 PR
945		CYTOPATH-TEACHING	1	140	140	0
946		ELECTR-MICRO-TS-PROC	1	90	90	0
947		ELECTR-MICRO-EMBED	1	90	90	0
948		ELECTR-MICRO-AREA	1	140	140	0
949		ELECTR-MICRO-DKRM	1	140	140	0
950		ELECTR-MICRO-FILES	1	30	30	0
951		ELECTR-MICRO-OFFICE	1	110	110	1 PR
TOTAL				8,140		

DPT LAB-CLINICAL

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
976	BB-DONOR-WAITING	1	280	280	20	ST
977	BB-DONOR-PRELIM-PROC	1	200	200	0	
978	BB-DONOR-TOILET-M	1	75	75	3	FX
979	BB-DONOR-TOILET-F	1	50	50	2	FX
980	BB-DONOR-PHLEBOTOMY	1	600	600	0	
981	BB-DONOR-RECVRY-REPR	1	430	430	0	
982	BB-DONOR-BLOOD-PROC	1	280	280	0	
983	BB-DONOR-COMPON-PREP	1	360	360	0	
984	BB-DONOR-BLOOD-STOR	1	100	100	0	
985	BB-DONOR-SHIP-RECEIV	1	400	400	0	
986	BB-DONOR-OFFICE	1	260	260	2	PR
987	BB-DONOR-MOBIL-STOR	1	400	400	0	
988	BB-TRANSF-OFFICE	1	330	330	3	PR
989	BB-TRANSF-RECS-FILES	1	110	110	0	
990	BB-TRANSF-CROSSMATCH	1	400	400	0	
991	BB-TRANSF-BLOOD-STOR	1	300	300	0	
992	BB-TRANSF-FROZN-PREP	1	300	300	0	
993	BB-TRANSF-ANTIBODY	1	240	240	0	
994	BB-TRANSF-TISSUE-TYP	1	280	280	0	
995	HEMATOL-STAINING	1	110	110	0	
996	HEMATOL-MICROSCOPY	1	400	400	0	
997	HEMATOL-AUTO-COUNT	1	220	220	0	
998	HEMATOL-SLIDE-STOR	1	40	40	0	
999	HEMATOL-TRANSF-PROC	1	280	280	0	

1001	HEM	1	220	220	0
1002	HEM	1	200	200	0
1003	HEM	1	330	330	3 PR
1004	URIN	1	220	220	0
1005	URINAL-GENERAL	1	110	110	0
1006	GNL-CHEM-COMM-ACCESS	1	300	300	0
1007	GNL-CHEM-AUTO-CHEM	1	1000	1,000	0
1008	GNL-CHEM-MANUAL-CHEM	1	1200	1,200	0
1009	GNL-CHEM-OFFICE	1	440	440	4 PR
1010	TOXICOL-OFFICE	1	110	110	1 PR
1011	TOXICOL-SPECIMN-STOR	1	40	40	0
1012	TOXICOL-GENERAL	1	1200	1,200	0
1013	RADIOCHEM-OFFICE	1	110	110	1 PR
1014	RADIOCHEM-GENERAL	1	1200	1,200	0
1015	SPEC-CHEM-OFFICE	1	220	220	2 PR
1016	SPEC-CHEM-GENERAL	1	1800	1,800	0
1017	BACTERIOL-OFFICE	1	220	220	2 PR
1018	BACTERIOL-AUTOCLAVE	1	370	370	0
1019	BACTERIOL-MEDIA-PREP	1	140	140	0
1020	BACTERIOL-INCUBATOR	1	200	200	0
1021	BACTERIOL-GENERAL	1	420	420	0
1022	BACTERIOL-ANAER-LAB	1	280	280	0
1023	BACTERIOL-MEDIA-STOR	1	140	140	0
1024	BACTERIOL-NOSO-SURV	1	280	280	0
1025	PARASITOLOGY-OFFICE	1	110	110	1 PR
TOTAL			17,725		

DPT LAB-CLINICAL

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1026	PARASITOLOGY-GENERAL	1	420	420	0	
1027	SEROL-VIROL-OFFICE	1	110	110	1	PR
1028	SEROL-VIROL-GENERAL	1	1000	1,000	0	
1029	SEROL-VIROL-FL-MICRO	1	80	80	0	
1030	MYCOLOGY-OFFICE	1	110	110	1	PR
1031	MYCOLOGY-GENERAL	1	420	420	0	
TOTAL			2,140			

DPT LAB-CLINICAL-MEDIUM

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1800	CP-RECS-WAIT-RECEPT	1	350	350	25	ST
1801	CONTROL	1	300	300	0	
1802	CP-RECS-PAT-TOILT-M	1	60	60	4	FX
1803	CP-RECS-PAT-TOILT-F	1	60	60	4	FX
1804	VENIPUNCTURE-STN	1	110	110	0	
1805	CP-RECS-BLOOD-DRAW	1	480	480	6	SN
1806	CP-ADM-LAB-SVC-CHIEF	1	200	200	1	PR
1807	CP-ADM-SECY-WAIT	1	110	110	1	PR
1808	CP-ADM-OFFICES	1	110	110	1	PR
1809	CP-ADM-CONF-RM	1	200	200	0	
1810	CP-ADM-TECHN-TRAIN	1	240	240	0	
1811	MORGUE-BODY-STOR	1	200	200	0	
1812	MORGUE-JANITORS-CLST	1	40	40	0	
912	MORGUE-AUTOPSY	1	400	400	2	TB
1813	MORGUE-LOBBY	1	100	100	0	ST

1815	SUR- WORK-SLA	1	200	200	1	PR
1816	SUR- SLIDE-STOR	1	110	110	0	
1817	BB-L RECVRV-REFR	1	200	200	0	
1818	BB-DONOR-BLOOD-PROC	1	140	140	0	
1819	BB-DONOR-BLOOD-STOR	1	240	240	0	
15	JANITOR-CLOSET	1	40	40	0	
1820	TOILET-SHOWER	1	45	45	3	FX
1821	LAB-TECH-WATCH-RM	1	110	110	0	
1822	PATH-WORK-MODULES	1	4000	4,000	20	PR
1823	STORAGE	1	200	200	0	
1824	BACTERIOL-AUTOCCLAVE	1	200	200	0	
1825	BACTERIOL-GENERAL	1	200	200	0	
1826	BACTERIOL-MEDIA-STOR	1	200	200	0	
TOTAL			8,955			

DPT LAB-CLINICAL-SMALL

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1827	CP-RECS-WAIT-RECPT	1	140	140	10	ST
1828	CP-RECS-PAT-TOILT-M	1	45	45	3	FX
1829	CP-RECS-PAT-TOILT-F	1	30	30	2	FX
1830	CP-ADM-LAB-SVC-CHIEF	1	140	140	1	PR
1831	SLIDE-FILE-STORAGE	1	60	60	0	
1832	CP-ADM-OFFICES	2	80	160	2	PR
1833	CP-ADM-CENTRAL-STOR	1	200	200	0	
1834	MORGUE-BODY-STORAGE	1	110	110	0	
1835	MORGUE-AUTOPSY	1	200	200	1	TB
1836	MORGUE-SHR-TOILT-LKR	1	45	45	3	FX
1812	MORGUE-JANITORS-CLST	1	40	40	0	
1837	SUR-PTH-GROSSING	1	200	200	0	
1838	CYTOPATH-STAINING	1	200	200	0	
1839	BB-DONOR-TOILET-M	1	30	30	2	FX
1840	BB-DONOR-PRELIM-PROC	2	80	160	0	
1841	BB-DONOR-RECVRV-REFR	1	110	110	0	
1842	BB-DONOR-BLOOD-PROC	1	80	80	0	
1843	BB-DONOR-COMPON-PREP	1	80	80	0	
1844	BB-DONOR-BLOOD-STOR	1	80	80	0	
1845	HEMATOL-MICROSCOPY	1	200	200	0	
1846	URINAL-GENERAL	1	200	200	0	
1847	GNL-CHEM-AUTO-CHEM	1	200	200	0	
1848	SPEC-CHEM-GENERAL	1	200	200	0	
1824	BACTERIOL-AUTOCCLAVE	1	200	200	0	
1849	BACTERIOL-MEDIA-PREP	1	110	110	0	
1850	BACTERIOL-GENERAL	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
1821	LAB-TECH-WATCH-RM	1	110	110	0	
1820	TOILET-SHOWER	1	45	45	3	FX
TOTAL			3,525			

DPT MEDICAL-PHOTOGRAPHY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1032	WAITING-ROOM	1	140	140	10	ST
1033	TOILETS-MALE	1	75	75	3	FX
1034	TOILETS-FEMALE	1	50	50	2	FX
1035	CONTROL-RECEPTION	1	110	110	0	

1037	CONF-ROENTGEN-RM	1	200	200	0
1038	MEET-2-STUDIO	1	800	800	0
1039	BLA-TE-DKROOM	1	80	80	0
1040	COLOR-OTO-SECTION	1	1500	1,500	0
1041	COPY-SECTION	1	700	700	0
1042	FILE-ROOM	1	200	200	0
1043	STORAGE-AREA	1	250	250	0
1044	REFRIG-AREA	1	200	200	0
1045	REFRIG-DEFROST-HOLD	1	110	110	0
1046	CHEMICAL-SUPPLY-RM	1	110	110	0
1047	PRINT-FINISHING-RM	1	180	180	0
1048	GENL-PHOTOGRAPHY-RM	1	110	110	0
1049	STAFF-WATCH-ROOM	1	110	110	0
1050	STAFF-WATCH-TOILET	1	45	45	3 FX
15	JANITOR-CLOSET	1	40	40	0
TOTAL			5,190		

DPT RADIOLOGY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1051	WAITING-ROOM	1	1180	1,180	78	ST
1052	CONTROL	1	200	200	0	
1053	FILM-FILES	1	2479	2,479	0	
1054	TEACH-FILM-FILES	1	300	300	0	
1055	RADIOLOGY-CHIEF-OFF	1	220	220	1	PR
1056	RADIOL-CHIEF-TOILET	1	30	30	2	FX
1057	SECY-WAITING-RM	1	110	110	1	PR
1058	ADMIN-ASSISTANT	1	110	110	1	PR
1059	RADIOLOGY-ASST-CHIEF	1	110	110	1	PR
1060	VIEW-CONSULTATION	1	600	600	0	
1061	MTST-STENO-SECY	1	200	200	2	PR
1062	STAFF-OFFICE	1	110	110	1	PR
1063	RESIDENT-OFFICE	1	110	110	1	PR
1064	LOUNGE-CONFERENCE-RM	1	200	200	0	
1065	INPAT-FILE-CONSULT	1	400	400	0	
1066	RADIOGRAPH-EXPOS-RM	12	270	3,240	0	
1067	RADIOGRAPH-RM-TOILET	6	40	240	2	FX
1068	FLURO-RADIOGRAPH-RM	3	300	900	0	
1069	FLURO-RM-TOILET	3	40	120	2	FX
1070	BARIUM-PREP-CLEAN-UP	1	80	80	0	
1071	PATIENT-HOLDING	1	50	50	0	
1072	DRESSING-BOOTH-MALE	1	300	300	15	BH
1073	DRESSING-BOOTH-FEM	1	300	300	15	BH
1074	CHEST-XRAY-ROOM	1	180	180	0	
1075	XRAY-FILM-PROCESSING	1	300	300	0	
1076	SORTING-AREA	1	300	300	0	
547	LITTER-WCHNR-STOR	1	80	80	0	
1543	EQUIP-SUPPLY-STORAGE	1	600	600	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
1077	PORTA-XRAY-MACH-STOR	1	150	150	5	MH
1078	XRAY-TECHN-WATCH-RM	1	110	110	0	
1079	XRAY-TECHN-TOILET	1	45	45	3	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL			13,614			

DPT OUTPAT-SPECIAL-PROC

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1544	WAIT-SPACE	1	110	110	8	ST
1089	TOHOC-CHY-ROOM	1	270	270	0	
1090	ULTRASOUND-DIAGN-RM	1	300	300	0	
1091	THERMOGRAPHY-ROOM	1	300	300	0	
1092	XEROGRAPHY-ROOM	1	300	300	0	
1093	COMPUTER-IN-OUT-STA	1	110	110	0	
1094	CINE-FILM-PROCESSING	1	110	110	0	
1095	CINE-FILM-VIEWING	1	200	200	0	
	TOTAL			1,700		

DPT RADIATION-THERAPY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1096	WAITING-SPACE	1	140	140	10	ST
1097	WAIT-ALCOVE-CRIT-ILL	1	160	160	0	
1098	CONTROL-RECEPTION	1	110	110	0	
1099	NURSES-OFFICE	1	110	110	0	
1100	PATIENT-TOILET-MALE	1	75	75	3	FX
1101	PATIENT-TOILET-FEM	1	50	50	2	FX
1102	SECRETARY	1	110	110	1	PR
1103	DOCTORS-OFFICE	1	110	110	1	PR
1104	THERAPY-EXAM-ROOMS	1	200	200	0	
1105	RESIDENTS-OFFICE	1	110	110	1	PR
1106	ENT-EXAM-ROOM	1	110	110	0	
1107	SUPR-ORTH-THER-DRESS	1	20	20	1	CU
1108	SUPR-ORTH-THER-TRTMT	1	360	360	0	
1109	SUPR-ORTH-THER-CNTRL	1	80	80	0	
1110	SUPR-ORTH-AUX-EQUIP	1	80	80	0	
1111	CBLT-60-THER-DRESS	1	40	40	2	CU
1112	CBLT-60-THER-TRTMT	1	400	400	0	
1113	CBLT-60-THER-CONTROL	1	80	80	0	
1114	CBLT-60-THER-MAZE	1	120	120	0	
1115	CBLT-60-THER-AUX-EQP	1	80	80	0	
1116	6MEV-LIN-ACC-DRESS	1	40	40	2	CU
1117	6MEV-LIN-ACC-TRTMT	1	400	400	0	
1118	6MEV-LIN-ACC-CONTROL	1	80	80	0	
1119	6MEV-LIN-ACC-MAZE	1	120	120	0	
1120	6MEV-LIN-ACC-AUX-EQP	1	80	80	0	
1121	18MEV-LIN-ACC-DRESS	1	40	40	2	CU
1122	18MEV-LIN-ACC-TRTMT	1	420	420	0	
1123	18MEV-LIN-ACC-CNTL	1	80	80	0	
1124	18MEV-LIN-ACC-MAZE	1	120	120	0	
1125	18MEV-LIN-ACC-AUX-EQ	1	180	180	0	
1126	TOILET-MALE	1	75	75	3	FX
1127	TOILET-FEMALE	1	50	50	2	FX
1128	DARKROOM-AUTO-PROC	1	80	80	0	
1129	THER-SIMULATOR-RM	1	300	300	0	
1130	THER-SIM-DRESS-CUBIC	1	20	20	0	
1131	TRTMT-PLANNING-ROOM	1	240	240	0	
1132	CLASSROOM	1	200	200	0	
1133	ELECTRONICS-LAB	1	200	200	0	
1134	RADIUM-SEALED-SOURCE	1	110	110	0	
1135	COMPUTER-IN-OUT-STA	1	110	110	0	
1136	PHYSICS-LAB-WRKRM	1	200	200	0	
1137	RADIATION-PHYSICS-OF	1	110	110	1	PR
1138	STAFF-TOILET-MALE	1	30	30	2	FX

15 JAN	CLOSET	1	40	40	0
TOTAL		6,010			

DPT NUCLEAR-MEDICINE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1167	WAITING-ROOM	1	140	140	10	ST
1168	PATIENT-TOILETS-MALE	1	75	75	3	FX
1169	PATIENT-TOILETS-FEM	1	50	50	2	FX
1170	RECEPTIONIST-SECY	1	160	160	2	PR
1171	NUCL-MED-HEAD-OP-EXM	1	200	200	1	PR
1172	NUCL-MED-ASST-HEAD	1	180	180	1	PR
1173	NUCLEAR-MED-TOILET	1	30	30	2	FX
1174	RESIDENTS-OFFICE	1	110	110	1	PR
1175	RESIDENT-EXAM-ROOMS	1	110	110	0	
1176	VIEWING-CONSULT-ROOM	1	100	100	0	
1177	FILE-ROOM	1	200	200	0	
1178	HOT-LAB	1	80	80	0	
1179	PATIENT-DOSING-ROOM	1	110	110	0	
1180	UPTAKE-ROOM	1	180	180	0	
1181	IMAGING-ROOM	1	270	270	0	
1182	COMPUTER-ROOM	1	180	180	0	
1183	DARK-ROOM	1	80	80	0	
1184	LAB-COUNTING	1	390	390	3	PR
1185	CLEAN-LINEN	1	30	30	0	
1186	SOILED-LINEN	1	30	30	0	
1187	RADIOCHEMISTRY	1	480	480	6	PR
1188	CONFERENCE-CLASSROOM	1	840	840	0	
1189	SCANNING-OFFICE	1	180	180	0	
1190	PHYSICISTS-OFFICE	1	110	110	1	PR
1191	PHYSICS-COUNTING-LAB	1	600	600	0	
1192	RADIOPHARMACIST-OFF	1	110	110	1	PR
1193	RADIOCHEMIST-OFF-LAB	1	300	300	0	
1194	SUPPLY-STORAGE	1	110	110	0	
1195	STAFF-LKR-LOUNGE	1	200	200	20	PR
1196	STAFF-TOILETS-MALE	1	175	175	7	FX
1197	STAFF-TOILETS-FEM	1	125	125	5	FX
1198	PATIENT-HOLDING	1	180	180	2	LT
1199	DECAY-DISPOSAL-ROOM	1	60	60	0	
1200	TECH-DUTY-ROOM	1	110	110	0	
1201	TECH-DUTY-TOILET-SHR	1	45	45	3	FX
1202	STORAGE	1	250	250	0	
1203	WUCH&IR-STRCHR-STOR	1	110	110	0	
1204	MED-PHYS-LAB-ELECTRN	1	300	300	0	
15	JANITOR-CLOSET	1	40	40	0	
TOTAL		7,030				

DPT CARDIAC-CATH-LAB

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1140	INSTRUCTORS-OFFICE	2	110	220	1	PR
1141	CINE-FILM-STORAGE	1	110	110	0	
1142	STAFF-TECHNS-LOUNGE	1	200	200	0	
1153	STAFF-TOILET-MALE	1	45	45	3	FX
1154	STAFF-TOILET-FEMALE	1	30	30	2	FX

1148	DARF	1	80	80	0
1149	FIL	1	140	140	0
1150	CATH	1	425	425	0
1151	MONITOR-BLOOD-GAS	1	140	140	0
548	EQUIP-SUPPLY-STOR	1	140	140	0
15	JANITOR-CLOSET	1	40	40	0
TOTAL			2,080		

DPT PHYSICAL-THERAPY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1215	ADM-RECEPT-AREA	1	110	110	0	
1573	OIC-OFFICE	1	110	110	1	PR
1574	NCOIC-OFFICE	1	110	110	1	PR
1216	ADM-STAFF-THERPST	3	85	255	1	PR
1217	CUBICLE	45	90	4,050	0	
1218	CUBICLE-WORK-STA	23	60	1,380	0	
1219	EXERCISE-STATION	18	60	1,080	0	
1220	REHAB-AREA	1	1000	1,000	0	
1221	STORAGE	1	106	106	0	
1222	HYDRO-EXTREM-WHLPL	7	60	420	0	
1223	HYDRO-LOWBOY-WHLPL	2	80	160	0	
1224	HYDRO-TRTHT-CUB	2	110	220	0	
1225	HYDRO-WHLPL-WRK-SN	3	60	180	0	
1226	HYDRO-CONT-BODY-TN	2	240	480	0	
1227	HYDRO-THER-POOL	1	1500	1,500	0	
1228	SUPP-WAIT-SPACES	1	210	210	15	SP
1229	SUPP-LITR-WHCHAIR	1	84	84	6	SP
1230	SUPP-EXAM-SP-RX	3	110	330	0	
1231	SUPP-WHCHAIR-TOILT	2	50	100	2	FX
1575	SUPP-DRESS-BOOTH	1	180	180	6	BH
1576	SUPP-PAT-LKR	1	180	180	10	LK
1232	SUPP-STAFF-TOILET	2	30	60	2	FX
1233	SUPP-STAFF-LKRS	1	120	120	12	LK
1577	SUPP-STAFF-LOUNGE	1	180	180	0	
499	CLEAN-STORAGE	1	110	110	0	
500	UTIL-SOILED-STOR	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
1578	SP-TRT-DAILY-LIVING	1	400	400	0	
1236	SP-TRT-AMPUTEE-TRNG	1	610	610	0	
1579	SP-TRT-CARDIO-POL	1	300	300	0	
1237	SP-TRT-ELECTROMYOG	1	110	110	0	
1238	SP-TRT-PED-REHAB	1	300	300	0	
1580	SP-TRT-EXAM-RES	1	110	110	0	
1239	CLIN-ED-SUPVR	1	110	110	1	PR
1240	CLIN-ED-CONF-LIBR	1	200	200	0	
1241	CLIN-ED-TRNG-AIDS	1	50	50	0	
1242	CLIN-ED-STDNT-CARR	5	30	150	0	
TOTAL			15,205			

DPT OCCUPATIONAL-THERAPY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1581	ADM-RECEPTION-AREA	1	110	110	0	
1582	ADM-WAITING-AREA	1	210	210	15	ST

1584	ADM-PT-THERAPIST	3	85	255	1 PR
1586	CLI-GENERAL	1	4575	4,575	0
1587	CLIN-COMB-PROGRAMS	1	500	500	0
1588	CLINIC-DAILY-LIVE	1	265	265	0
1589	CLINIC-ENC-POWER-RM	1	580	580	0
1590	CLINIC-NURSE-UNIT	1	150	150	0
1591	CLINIC-EVAL-AREA	1	110	110	0
1592	SPEC-PROG-SID	1	500	500	0
1593	SPEC-PROG-WORK-THER	1	110	110	0
1594	SPEC-PROG-ORTHOTICS	1	110	110	0
1595	SPEC-PROG-CLIN-RSH	1	110	110	0
1596	SPEC-PROG-CHILD-LIFE	1	230	230	0
1597	CLIN-ED-SUPV-OFFICE	1	110	110	0
1598	CLIN-ED-CONF-LIBR	1	200	200	0
1599	CLIN-ED-TRNG-AIDS	1	50	50	0
1600	CLIN-ED-STUD-CARREL	4	30	120	4 CR
1601	SPT-STORAGE-ROOM	1	150	150	0
1602	SPT-WHCHR-TOILET	1	50	50	0
1603	SPT-STAFF-TOILET-M	1	30	30	2 FX
1604	SPT-STAFF-TOILET-F	1	30	30	2 FX
1606	SPT-STAFF-LOCKERS	1	150	150	15 LK
1615	WORK-EXAM-AREA-INTEN	1	0	0	0 BS
1605	SPT-STAFF-LOUNGE	1	110	110	0
TOTAL			9,035		

DPT INPAT-SPECIAL-PROC

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1080	PERIPH-SPEC-PROCED	1	425	425	0	
1081	NEURO-SPEC-PROCED-RM	1	425	425	0	
1082	MONITORING-AREA	1	80	80	0	
1083	CONTROL-AREA	1	60	60	0	
1084	SCRUB-AREA	1	60	60	0	
1085	UTILITY-AREA	1	80	80	0	
1086	DRESS-TOILET-AREA	1	110	110	1 FX	
1087	FILM-PROCESSING	1	110	110	0	
1088	CARDIOVASC-LAB	1	110	110	0	
TOTAL			1,460			

DPT SURGICAL-SUITE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1258	FAMILY-WAITING	1	140	140	10 ST	
1607	CONSULTATION-ROOM	1	140	140	0	
1259	OR-INSTRUCTOR-OFF	1	110	110	1 PR	
1260	CLASSRM-CCTV	1	400	400	0	
1261	NURSES-STATION	1	200	200	2 PR	
1262	OR-SUPV-SUR-STE-CLRK	1	180	180	2 PR	
1263	SR-SUPPLY-CORPSMEN	1	160	160	2 PR	
1265	PATIENT-HOLD-STRETCH	1	200	200	0	
1267	OUTPAT-WAIT-CONTROL	1	200	200	0	
1266	OUTPAT-CHNG-RM-TOILT	1	140	140	0	
1268	OUTPAT-PREP	1	200	200	0	
1608	OUTPAT-RECOVERY	1	440	440	4 BD	
1269	DOCTORS-LOUNGE	1	200	200	0	

1271	DOCTORS-TOILET-SHRS	1	150	150	6	PX
1272	LOUNGE	1	200	200	0	
1273	LOCKERS	1	200	200	20	LK
1274	FEMALE-TOILET-SHR	1	150	150	6	PX
1275	CORPSMEN-LOUNGE	1	200	200	0	
1276	CORPSMEN-LOCKERS	1	200	200	20	LK
1277	CORPSMEN-TOILET-SHR	1	150	150	6	PX
1278	GEN-SURG-OPER-ROOM	1	400	400	0	
1279	GEN-SURG-OR-SP-PROC	1	600	600	0	
1280	PERIPHERAL-VASC-OR	1	600	600	0	
1281	ORTHOPEDIC-OR	1	450	450	0	
1282	ORTH-OR-PLAS-SPLNT	1	200	200	0	
1283	ORTH-OR-DKRM-AUTO	1	40	40	0	
1284	NEUROSURGICAL-OR	1	600	600	0	
1285	NEURO-SURG-REC-EQPT	1	110	110	0	
1286	CARDIAC-OR	1	600	600	0	
1287	CARDIAC-OR-WORK-AREA	1	200	200	0	
1288	CARDIAC-OR-TV-MONITR	1	200	200	0	
1289	CARDIAC-PERFUS-OFF	1	200	200	1	PR
1609	ORGAN-PROFUSION	1	200	200	0	
1290	SCRUB-UP-SUBSTERILE	6	100	600	0	
1291	SURGICAL-WORK-AREA	1	800	800	0	
1292	CLEAN-STORAGE	1	1000	1,000	0	
1293	FROZEN-SECTION-LAB	1	50	50	0	
1611	CONTAM-WASTE-COLLECT	1	140	140	0	
1612	CLEANING-EQUIP	1	110	110	0	
1303	DOCTORS-BEDROOM	1	110	110	2	PR
1304	DOCTORS-TOILET-SHR	1	45	45	3	PX
TOTAL			11,415			

DPT SURGICAL-RECOVERY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1307	RECOVERY-ROOM	1	1000	1,000	10	BD
1308	UTILITY-WORK-AREA	1	200	200	0	
1309	DICTATION-BOOTH	1	180	180	6	BH
1310	EQUIPMENT-STORAGE	1	400	400	0	
1311	NURSE-STA-MED-PREP	1	180	180	0	
1312	STAFF-TOILET	1	30	30	2	PX
1314	CONSULTATION-ROOM	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
TOTAL			2,140			

DPT DIALYSIS

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1322	DOCTORS-OFFICE	1	110	110	1	PR
1323	EXAMINATION-ROOM	1	110	110	0	
1324	NURSES-STA-MED-STOR	1	200	200	0	
1325	DIALYSIS-ASSEMBLY	1	200	200	0	
1326	DIALYSIS-SUITE	1	1120	1,120	8	SN
1327	RENAL-STUDIES-ROOM	1	200	200	0	
1328	PATIENT-TOILET-MALE	1	30	30	2	PX
1329	PATIENT-TOILET-FEM	1	30	30	2	PX
1330	EQUIPMENT-STORAGE	1	400	400	0	
TOTAL			2,400			

BNO	NAM.	NO	SIZE	PRODUCT	PAR	PU
1331	FATHER-WAITING	1	140	140	10	ST
1332	FATHER-TOILET	1	30	30	2	FX
1333	NURSES-STA-MONITOR	1	140	140	0	
1613	DOCTOR-OFFICE	1	110	110	1	PR
1334	DOCTOR-BEDROOMS	1	110	110	1	PR
1335	DOCTOR-TOILET-SHR	1	45	45	3	FX
1336	CONSULTATION	1	110	110	0	
1337	STRETCHER-STOR	1	110	110	0	
1338	PATIENT-PREP-EXAM-RM	1	155	155	0	
1339	PATIENT-TOILET	1	45	45	3	FX
1340	LABOR-ROOM	10	195	1,950	0	
1341	LABOR-ROOM-TOILET	10	30	300	2	FX
1342	UTILITY-APPAR-STOR	1	200	200	0	
1343	DELIVERY-ROOM	4	400	1,600	0	
1344	SCRUBUP-SUBSTERIL	8	200	1,600	0	
1346	RESUSCITATION-ISLAND	1	140	140	0	
1347	RECOVERY-ROOM	1	400	400	4	BD
1348	RECOVERY-RM-TOILET	1	30	30	2	FX
1349	CLN-LIN-STERILE-STOR	1	240	240	0	
1350	CLNUP-SOILED-LIN-COL	1	280	280	0	
1351	EQUIP-SUPPLY-STOR	1	200	200	0	
1352	ANESTHESIA-STORAGE	1	80	80	0	
1353	MALE-LOUNGE-LKR	1	200	200	0	
1355	MALE-TOILET-SHOWER	1	125	125	5	FX
1356	FEMALE-LOUNGE-LKR	1	200	200	0	
1358	FEMALE-TOILET-SHOWER	1	125	125	5	FX
1359	LABORATORY	1	110	110	0	
1614	CLEAN-EQUP-STORAGE	1	80	80	0	
	TOTAL			8,855		

DPT NURSERY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1360	NURSES-STATION	1	110	110	0	
1361	NURSE-STATION-TOILET	1	30	30	2	FX
1362	ANTEROOM-SCRUBUP	1	110	110	0	
1363	WORK-EXAM-AREA-PULL	1	560	560	56	BS
1615	WORK-EXAM-AREA-INTEN	1	190	190	19	BS
1364	FULL-TERM-BASSINET	56	30	1,680	0	
1365	INTEN-CARE-BASSINET	19	80	1,520	0	
1366	OBSERVATN-BASSINET	2	50	100	0	
1367	CIRCUMCISION-AREA	1	80	80	0	
1368	XRAY-ALCOVE	1	110	110	0	
1369	PROCEDURE-ROOM	1	140	140	0	
1370	FORMULA-DISPNS-STOR	1	160	160	0	
1371	LINEN-STORAGE	1	80	80	0	
1372	EQUIPMENT-STORAGE	1	200	200	0	
1373	UTILITY-ROOM	1	140	140	0	
1374	MOTHERS-ROOM	1	140	140	0	
1375	DOCTORS-OFF-CONSULT	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
	TOTAL			5,500		

***** 41

BNO	NI	NO	SIZE	PRODUCT	PAR	PU
1376	WELFARE-REC-OFFICE	1	300	300	0	
1377	RED-CROSS-WAITING	1	280	280	20	ST
1378	RED-CROSS-FIELD-DIR	1	140	140	1	PR
1379	RED-CROSS-SECY-WAIT	1	110	110	1	PR
1380	RED-CROSS-ADMIN	1	320	320	4	PR
1381	RED-CROSS-REC-SUPV	1	110	110	1	PR
1382	RED-CROSS-CASE-SUPV	1	110	110	1	PR
1383	RED-CROSS-SOCL-WORK	1	480	480	6	PR
1384	RED-CROSS-REC-WORKR	1	480	480	6	PR
1385	RED-CROSS-VOLUN-RM	1	200	200	0	
1386	RED-CROSS-VOLUN-OFF	1	320	320	4	P
1387	RED-CROSS-MUSIC-RM	1	400	400	0	
1388	RED-CROSS-TV-ROOM	1	400	400	0	
1389	RED-CROSS-READING-RM	1	400	400	0	
1390	RED-CROSS-CRAFT-SHOP	1	400	400	0	
1616	PUBLIC-TOILET-MALE	1	75	75	3	FX
1617	PUBLIC-TOILET-FEMALE	1	50	50	2	FX
15	JANITOR-CLOSET	1	40	40	0	
1391	TOILETS-MALE	1	75	75	3	FX
1392	TOILETS-FEMALE	1	50	50	2	FX
1393	KITCHEN	1	110	110	0	
1394	STORAGE	1	400	400	0	
1395	REC-LOUNGE-MULTIUSE	1	2000	2,000	0	
1396	CAFETERIA-SNACK-BAR	1	3000	3,000	0	
1397	CAFETERIA-STORAGE	1	900	900	0	
1398	EXCHANGE-SALES	1	3600	3,600	0	
1399	EXCHANGE-STORAGE	1	600	600	0	
1400	FLORIST-SHOP	1	420	420	0	
1401	BARBER-SHOP	1	420	420	0	
1402	BEAUTY-SHOP	1	420	420	0	
1403	LAUNDRY-CLEAN-PICKUP	1	680	680	0	
1404	REC-TOILETS-MALE	1	75	75	3	FX
1405	REC-TOILETS-FEMALE	1	50	50	2	FX
1406	CHAPEL-NAVE	1	1000	1,000	100	ST
1407	CHAPEL-CHANCEL	1	200	200	0	
1408	CHAPEL-VOTIVE-CONFES	1	160	160	0	
1409	CHAPEL-VESTMENTS-STOR	1	180	180	0	
1410	CHAPEL-OFFICES	1	110	110	1	PR
1411	CHAPEL-SECY-CLERK	1	110	110	1	PR
1412	CHAPEL-SEMINAR-ROOMS	1	200	200	0	
1413	CHAPEL-TOILET-MALE	1	30	30	2	FX
	TOTAL		19,405			

DPT SUBSISTENCE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1416	CAFETERIA-SERVE-FAC	1	1300	1,300	0	
1417	PAT-TRAY-SERVICE	1	900	900	0	
1418	PAT-FOOD-CART-STOR	1	780	780	26	CT
1419	SANI-DISHWASH-COLLTN	1	1160	1,160	0	
1420	SANI-POT-WASH-CTR	1	240	240	0	
1421	SANI-CART-WASH-CTR	1	210	210	0	
1422	SANI-CAN-WASH-TRASH	1	60	60	0	
1423	SANI-REFRIG-GARB-ST	1	64	64	0	

1426	PROCESS-PREP	1	3600	3,600	0
1427	ENT-ROOM	1	130	130	0
1428	RECEIVE-STORKPR-SP	1	280	280	0
1429	RECEIVE-STOR-DRY	1	1250	1,250	0
1430	RECEIVE-STOR-NONFOOD	1	700	700	0
1431	REFRIG-FROZEN-STOR	1	1060	1,060	0
1432	REFRIG-EQUIP-ROOM	1	100	100	0
1433	DINING-ROOM	1	2	2	562 ST
1434	ADM-FOOD-SVC-CHIEF	1	150	150	1 PR
1435	ADM-FOOD-SVC-CH-SECY	1	110	110	1 PR
1436	ADM-PATIENT-CONSULT	2	100	200	0
1437	ADM-OTHER-DESK-SPACE	7	80	560	0
1438	FS-EMPL-LOCKERS-MALE	1	140	140	14 LK
1439	FS-EMPL-TLT-SHR-MALE	1	100	100	4 FX
1440	FS-EMPL-LOCKERS-FEM	1	140	140	14 LK
1441	FS-EMPL-TLT-SHR-FEM	1	75	75	3 FX
TOTAL			13,596		

DPT CENTRAL-PROCESSING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1442	RECEIVE-STATION	1	100	100	0	
1443	RECEIVE-CLEANUP	1	600	600	0	
1444	RECEIVE-CART-WASH	1	220	220	0	
1447	PREP-STERIL-WORK-ARA	1	600	600	0	
1450	PREP-STERILIZER-CTR	1	300	300	0	
1454	STOR-STERIL-UNSTERIL	1	2000	2,000	0	
1455	STOR-MED-EQUIP	1	800	800	0	
1457	STOR-DISPENS-CENTER	1	140	140	0	
1459	STOR-SUPVR-OFFICE	1	110	110	1	PR
1460	STOR-CLERICAL-OFF	1	160	160	2	PR
1461	STOR-LOCKER-MALE	1	140	140	14	LK
1462	STOR-LOCKER-FEM	1	140	140	14	LK
1463	STOR-TOILET-MALE-SHR	1	100	100	4	FX
1464	STOR-TOILET-FEM-SHR	1	75	75	3	FX
15	JANITOR-CLOSET	1	40	40	0	
TOTAL			5,525			

DPT CENTRAL-SUPPLY-STOR

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1467	MEDICAL-GENL-STORAGE	1	9000	9,000	0	
1468	RECEIVING-ISSUE	1	800	800	0	
1469	EQUIPMENT-STORAGE	1	1000	1,000	0	
1470	FORMS-STORAGE	1	300	300	0	
1471	SECURITY-STORAGE	1	300	300	0	
1472	OXYGEN-STOR-EMERG-CY	1	200	200	0	
1473	RECEIVE-SHIP-DOCK	1	300	300	0	
TOTAL			11,900			

DPT LINEN-SERVICE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
-----	------	----	------	---------	-----	----

1475	CLEAN-WOMEN-STOR-SRT	1	400	400	0
1476	SOIL-WOMEN-COL-SRT	1	200	200	0
	TOTAL		710		

DPT HOUSEKEEPING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1477	HOUSEKEEP-OFFICER	1	110	110	1	PR
1478	EXEC-HOUSEKEEP-FORMN	1	160	160	2	PR
1479	SECRETARY	1	110	110	1	PR
1480	JANITOR-FOREMAN	1	480	480	6	PR
1481	TRAINING-CLASSROOM	1	750	750	0	
1482	DAY-ISSUE-ROOM	1	750	750	0	
1483	BULK-STORAGE-AREA	1	2000	2,000	0	
1484	EQUIP-CLEAN-ROOM	1	400	400	0	
1485	EQUIP-CHANGE-ROOM	1	220	220	0	
1486	GENERAL-EQUIP-STOR	1	450	450	0	
	TOTAL			5,430		

DPT TRASH-COLLECTION

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1487	TRASH-COLLECTION	1	900	900	0	
	TOTAL			900		

DPT PREVENTIVE-MEDICINE

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1488	PREVENT-MED-OFFICER	1	140	140	1	PR
1489	PREVENT-MED-TECHNS	1	200	200	2	PR
1490	NURSES-OFFICE	1	110	110	1	PR
1491	INTERVIEW-ROOM	1	110	110	0	
1492	LABORATORY	1	400	400	0	
1493	STORAGE	1	200	200	0	
1494	TOILET-MALE	1	30	30	2	FX
1495	TOILET-FEMALE	1	30	30	2	FX
	TOTAL			1,220		

DPT RADIOLOGICAL-SAFETY

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1496	RADIATION-SAFETY-OFF	1	140	140	1	PR
1497	SECRETARY	1	110	110	1	PR
1498	ASST-RADIATN-SAFETY	1	110	110	1	PR
1499	HMCS-HMC	1	200	200	2	PR
1500	HMT-HM2	1	200	200	2	PR
1501	PHOTODOSIMETRIST	1	110	110	1	PR
1502	DARK-ROOM	1	500	500	0	
1503	THERMOLUM-DOSIMETRY	1	200	200	0	
1504	FILM-READING-ROOM	1	350	350	0	
1505	ELECTRONIC-EQUIPMENT	1	350	350	0	
1506	FILES	1	175	175	0	

OS/360 - RELEASE 21.6

NATIONAL INSTITUTES OF HEALTH
DIVISION OF COMPUTER RESEARCH AND TECHNOLOGY
CENTRAL COMPUTER FACILITY

PROGRAMMER - LWKK61

DATE - 12/07/76

JOB NAME - LWK200

ACCOUNT NUMBER - WPE1

JOB CPU TIME - 1.45 SECONDS

COMPUTER - 370/168 - 4

INITIAL TIME - 15:05:32

FINAL TIME - 15:10:49

JOB COMPLETION CODE - S 000

TOTAL CARDS READ - 12

TOTAL CARDS PUNCHED - 0

TOTAL LINES PRINTED - 2632

CHARGE (MACHINE UNITS - 3.262 DOLLARS - \$4.89)

APPROXIMATELY EQUIVALENT 165 CPU TIME - 2 SECONDS

NAVAL REGIONAL MEDICAL CENTER
PORTSMOUTH, VIRGINIA

1555	SUPP-CLN-SUPPLY	1	200	200	0
1555	SUPP-CLN-LINEN	1	110	110	0
1556	SUPP-C-NOURISHMNT	1	110	110	0
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0
15	JANITOR-CLOSET	1	40	40	0
1560	NURSE-STA-MONITOR	1	140	140	0
1561	NURSE-STA-WORK-AREA	1	200	200	0
1562	NURSE-STA-MED-PREP	1	60	60	0
1563	NURSE-STA-TOILET	1	30	30	2 FX
1564	DAYROOM	1	400	400	0
1565	OFF-CONF-CLASSRM	1	200	200	0
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1 PR
1567	OFF-CONF-RESIDENT	1	110	110	1 PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1 PR
1569	STAFF-LOCKERS-MALE	1	110	110	11 LK
1570	STAFF-LOCKERS-FEM	1	110	110	11 LK
1571	STAFF-TOILET-MALE	1	30	30	2 FX
1572	STAFF-TOILET-FEM	1	30	30	2 FX
TOTAL			8,645		

DPT MED-SURG-NURSING-03

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1564	DAYROOM	1	400	400	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			8,645			

DPT MED-SURG-NURSING-04

BNO NAME NO SIZE PRODUCT PAR PU

1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1564	DAYROOM	1	400	400	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			8,645			

DPT MED-SURG-NURSING-05

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1564	DAYROOM	1	400	400	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK

1572 STAFF	1	30	30	2 FX
11LET-FEM	1	30	30	2 FX
TOTAL			8,645	

DPT MED-SURG-NURSING-06

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1564	DAYROOM	1	400	400	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
	TOTAL			8,645		

DPT MED-SURG-NURSING-07

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	

1562	NURSE-STA-MED-PREP	1	60	60	0
1563	NURSE-TOILET	1	30	30	2 FX
1564	DAYRO	1	400	400	0
1565	OFF-CO. CLASSRM	1	200	200	0
1566	OFF-CONF-NRS-MED-OFR	1	140	140	1 PR
1567	OFF-CONF-RESIDENT	1	110	110	1 PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1 PR
1569	STAFF-LOCKERS-MALE	1	110	110	11 LK
1570	STAFF-LOCKERS-FEM	1	110	110	11 LK
1571	STAFF-TOILET-MALE	1	30	30	2 FX
1572	STAFF-TOILET-FEM	1	30	30	2 FX
TOTAL			8,645		

DPT MED-SURG-NURSING-08

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1546	1-BED-ROOM	6	150	900	1	BD
1547	2-BED-ROOM	10	220	2,200	2	BD
1548	4-BED-ROOM	3	440	1,320	4	BD
1549	TOILET-SHOWER	21	45	945	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1564	DAYROOM	1	400	400	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OFR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			8,645			

DPT CORONARY-NURSING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1618	1-BEDROOM	10	200	2,000	1	BD
1619	TOILETS	10	30	300	2	FX
1620	SHR-DRY-AREA	1	40	40	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1558	SUPP-FAC-LABORATORY	1	110	110	0	

1560	NURSE	MONITOR	1	140	140	0
1561	NUR	WORK-AREA	1	200	200	0
1562	NUR.	MED-PREP	1	60	60	0
1563	NURSE-STA	TOILET	1	30	30	2 FX
1565	OFF-CONF	CLASSRM	1	200	200	0
1622	CONSULTATION	ROOM	1	110	110	0
1623	DOCTOR-OFFICE		1	110	110	1 PR
1624	FAMILY-WAITING		1	140	140	0
1625	FAMILY-WAITING	TOILT	1	30	30	2 FX
1569	STAFF-LOCKERS	MALE	1	110	110	11 LK
1570	STAFF-LOCKERS	FEM	1	110	110	11 LK
1571	STAFF-TOILET	MALE	1	30	30	2 FX
1572	STAFF-TOILET	FEM	1	30	30	2 FX
TOTAL				4,500		

DPT INTENSIVE-NURSING-1

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1626	1-BED-ROOM	5	200	1,000	1	BD
1627	WARD-BEDS	1	3750	3,750	25	BD
1628	TOILETS	5	30	150	2	FX
1620	SHR-DRY-AREA	1	40	40	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1621	SUPP-FAC-DCU-EQUIP	1	200	200	0	
1559	SUPP-FAC-LABORATORY	1	110	110	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1565	OFF-CONF-CLASSRM	1	200	200	0	
1622	CONSULTATION-ROOM	1	110	110	0	
1623	DOCTOR-OFFICE	1	110	110	1	PR
1624	FAMILY-WAITING	1	140	140	0	
1625	FAMILY-WAITING-TOILT	1	30	30	2	FX
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL				7,100		

DPT CARD-THOR-NURSING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	1	200	200	1	BD
1629	1-BED-ROOM	1	150	150	1	BD
1630	2-BED-ROOM	0	220	0	2	BD
1631	4-BED-ROOM	0	440	0	4	BD
1632	TOILET-SHOWER	2	45	90	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	

1556	SUPP-	1	110	110	0
1557	SUPP-	1	110	110	0
1558	SUPP-	1	140	140	0
15	JANITOR-CLOSET	1	40	40	0
1560	NURSE-STA-MONITOR	1	140	140	0
1561	NURSE-STA-WORK-AREA	1	200	200	0
1562	NURSE-STA-MED-PREP	1	60	60	0
1563	NURSE-STA-TOILET	1	30	30	2 FX
1633	DAYROOM	1	0	0	0
1638	NURSE-OFFICE	2	110	220	1 PR
1569	STAFF-LOCKERS-MALE	1	110	110	11 LK
1570	STAFF-LOCKERS-FEM	1	110	110	11 LK
1571	STAFF-TOILET-MALE	1	30	30	2 FX
1572	STAFF-TOILET-FEM	1	30	30	2 FX
1634	CHIEF-THORACIC-OFF	1	140	140	1 PR
1635	PATIENT-TOILET	1	30	30	2 FX
1636	SECRETARY-WAITING	1	110	110	0
1637	CONFERENCE-ROOM	1	200	200	0
1623	DOCTOR-OFFICE	4	110	440	1 PR
1639	EXAM-ROOM	2	110	220	0
TOTAL			3,720		

DPT OBSTETRICS-NURSING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1640	1-BED-ROOM	14	150	2,100	1	BD
1641	2-BED-ROOM	18	220	3,960	2	BD
1642	4-BED-ROOM	5	440	2,200	4	BD
1643	TOILET-SHOWER	39	45	1,755	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-PAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-PAC-TRASH-COLL	1	110	110	0	
1554	SUPP-PAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-PAC-CLN-LINEN	1	110	110	0	
1556	SUPP-PAC-NOURISHMNT	1	110	110	0	
1557	SUPP-PAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-PAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1644	DAY-ROOM	1	723	723	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			13,618			

DPT PEDIATRIC-NURSING

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1545	ISOLATION-ROOM	2	200	400	1	BD
1645	1-BED-ROOM	10	150	1,500	1	BD
1646	2-BED-ROOM	13	220	2,860	2	BD
1647	4-BED-ROOM	3	440	1,320	4	BD
1648	ANTE-ROOM	2	50	100	1	FX
1649	TOILET-SHOWER	26	45	1,170	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1650	ADM-ORIENTATION	1	140	140	0	
1651	PLAY-AREA	1	600	600	0	
1652	STORAGE-PLAY-THINGS	1	60	60	0	
1653	VISITORS-LOUNGE	1	250	250	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL				10,880		

DPT PSYCHI-MAX-NURSING-1

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1655	1-BED-ROOM	2	150	300	1	BD
1656	2-BED-ROOM	1	220	220	2	BD
1657	4-BED-ROOM	4	440	1,760	4	BD
1654	ISOLATION-ROOM	2	110	220	0	
1658	TOILET-SHOWER	7	45	315	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX

1555	OFF-CLASSRM	1	200	200	0
1566	OFF-RS-MED-OPR	1	140	140	1 PR
1567	OFF-C-RESIDENT	1	110	110	1 PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1 PR
1569	STAFF-LOCKERS-MALE	1	110	110	11 LK
1570	STAFF-LOCKERS-FEM	1	110	110	11 LK
1571	STAFF-TOILET-MALE	1	30	30	2 FX
1572	STAFF-TOILET-FEM	1	30	30	2 FX
TOTAL				5,915	

DPT PSYCHI-CON-NURSING-1

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1660	1-BED-ROOM	4	150	600	1	BD
1661	2-BED-ROOM	2	220	440	2	BD
1662	4-BED-ROOM	8	440	3,520	4	BD
1654	ISOLATION-ROOM	2	110	220	0	
1663	TOILET-SHOWER	14	45	630	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1664	DAY-ROOM	1	800	800	0	
1622	CONSULTATION-ROOM	2	110	220	0	
1565	OFF-CONF-CLASSRM	1	200	200	0	
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1	PR
1567	OFF-CONF-RESIDENT	1	110	110	1	PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1	PR
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL				8,910		

DPT PSYCHI-CON-NURSING-2

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1660	1-BED-ROOM	4	150	600	1	BD
1661	2-BED-ROOM	2	220	440	2	BD
1662	4-BED-ROOM	8	440	3,520	4	BD
1654	ISOLATION-ROOM	2	110	220	0	
1663	TOILET-SHOWER	14	45	630	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	

1555	SUPP-CLN-LINEN	1	110	110	0
1556	SUPP-OURISHMNT	1	110	110	0
1557	SUPP-LTR-WHCHR	1	110	110	0
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0
15	JANITOR-CLOSET	1	40	40	0
1560	NURSE-STA-MONITOR	1	140	140	0
1561	NURSE-STA-WORK-AREA	1	200	200	0
1562	NURSE-STA-MED-PREP	1	60	60	0
1563	NURSE-STA-TOILET	1	30	30	2 FX
1664	DAY-ROOM	1	800	800	0
1622	CONSULTATION-ROOM	2	110	220	0
1565	OFF-CONF-CLASSRM	1	200	200	0
1566	OFF-CONF-NRS-MED-OPR	1	140	140	1 PR
1567	OFF-CONF-RESIDENT	1	110	110	1 PR
1568	OFF-CONF-NRS-SVC-SPV	1	110	110	1 PR
1569	STAFF-LOCKERS-MALE	1	110	110	11 LK
1570	STAFF-LOCKERS-FEM	1	110	110	11 LK
1571	STAFF-TOILET-MALE	1	30	30	2 FX
1572	STAFF-TOILET-FEM	1	30	30	2 FX
TOTAL			8,910		

DPT LIGHT-CARE-NURSING-1

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1670	1-BED-ROOM	8	150	1,200	1	BD
1671	2-BED-ROOM	11	220	2,420	2	BD
1672	4-BED-ROOM	5	440	2,200	4	BD
1673	TOILET-SHOWER	24	45	1,080	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1674	DAY-ROOM	1	400	400	0	
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			9,220			

DPT LIGHT-CARE-NURSING-2

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1670	1-BED-ROOM	8	150	1,200	1	BD
1671	2-BED-ROOM	11	220	2,420	2	BD
1672	4-BED-ROOM	5	440	2,200	4	BD

1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1674	DAY-ROOM	1	400	400	0	
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			9,220			

DPT LIGHT-CARE-NURSING-3

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1670	1-BED-ROOM	8	150	1,200	1	BD
1671	2-BED-ROOM	11	220	2,420	2	BD
1672	4-BED-ROOM	5	440	2,200	4	BD
1673	TOILET-SHOWER	24	45	1,080	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1674	DAY-ROOM	1	400	400	0	
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			9,220			

DPT LIGHT-CARE-NURSING-4

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1670	1-BED-ROOM	8	150	1,200	1	BD
1671	2-BED-ROOM	11	220	2,420	2	BD
1672	4-BED-ROOM	5	440	2,200	4	BD
1673	TOILET-SHOWER	24	45	1,080	3	FX

1550	TUB	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1674	DAY-ROOM	1	400	400	0	
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			9,220			

DPT LIGHT-CARE-NURSING-5

BNO	NAME	NO	SIZE	PRODUCT	PAR	PU
1670	1-BED-ROOM	8	150	1,200	1	BD
1671	2-BED-ROOM	11	220	2,420	2	BD
1672	4-BED-ROOM	5	440	2,200	4	BD
1673	TOILET-SHOWER	24	45	1,080	3	FX
1550	TUBROOM	1	110	110	1	FX
1551	WHEELCHAIR-SHOWER	1	80	80	1	FX
1552	SUPP-FAC-SOILED-UTIL	1	200	200	0	
1553	SUPP-FAC-TRASH-COLL	1	110	110	0	
1554	SUPP-FAC-CLN-SUPPLY	1	200	200	0	
1555	SUPP-FAC-CLN-LINEN	1	110	110	0	
1556	SUPP-FAC-NOURISHMNT	1	110	110	0	
1557	SUPP-FAC-LTR-WHCHR	1	110	110	0	
1558	SUPP-FAC-TRTMT-EXAM	1	140	140	0	
15	JANITOR-CLOSET	1	40	40	0	
1560	NURSE-STA-MONITOR	1	140	140	0	
1561	NURSE-STA-WORK-AREA	1	200	200	0	
1562	NURSE-STA-MED-PREP	1	60	60	0	
1563	NURSE-STA-TOILET	1	30	30	2	FX
1674	DAY-ROOM	1	400	400	0	
1569	STAFF-LOCKERS-MALE	1	110	110	11	LK
1570	STAFF-LOCKERS-FEM	1	110	110	11	LK
1571	STAFF-TOILET-MALE	1	30	30	2	FX
1572	STAFF-TOILET-FEM	1	30	30	2	FX
TOTAL			9,220			

PORTSMOUTH HOSPITAL

DESIGN PLANNING

LIGHT CARE AND ALCOHOLIC REHABILITATION BEDS

EXISTING HOSPITAL BUILDING

15th Floor	34 beds - Light Care (SOQ Area)
14th Floor	34 beds - Light Care (SOQ Area)
13th Floor	34 beds - Light Care (SOQ Area)
12th Floor	34 beds - Light Care (SOQ Area)
11th Floor	66 beds - (Wards & SOQ Area)
10th Floor	<u>31</u> beds - SOQ Area
	<u>233</u> beds - Light Care
10th Floor	<u>15</u> beds - Alcoholic Rehab. Unit (Wards area)
9th Floor	50 beds - Psychiatric Unit (Wards & SOQ Area)
8th Floor	<u>50</u> beds - Psychiatric Unit (Wards & SOQ Area)
	<u>100</u> beds

(7th Floor and below to be used for Outpatient & Ancillary)

A possible plan for the lower existing floors would be as follows:

- 7th Floor - Pediatrics Clinic & Services (Wards & Present Outpatient)
- 6th Floor - OB/GYN Clinics & Services (Wards & Present Outpatient)
- 5th Floor - Laboratory renovation - extend into new areas.
- 4th Floor - Radiology renovation - extend into new areas.
- 3rd Floor - OR Suite renovation - extend into new areas.
- 2nd Floor - Dining Room & Kitchen renovation - extend into new areas)
- 1st Floor - Administration, Medical Records renovation - extend into new areas.

NOTE: If functional changes are required, after a core study, these areas can be totally redone into other uses for a more acceptable functional plan.

DESIGN PLANNING

NEW NURSING UNIT & ANCILLARY

(FRONT OF PRESENT HOSPITAL)

15th Floor	40 beds - Medical/Surgical Unit
14th Floor	40 beds - Medical/Surgical Unit
13th Floor	40 beds - Medical/Surgical Unit
12th Floor	40 beds - Medical/Surgical Unit
11th Floor	40 beds - Medical/Surgical Unit
10th Floor	40 beds - Medical/Surgical Unit
9th Floor	40 beds - Medical/Surgical Unit
8th Floor	40 beds - Medical/Surgical Unit
7th Floor	50 beds - Pediatrics
6th Floor	72 beds - O.B. Unit (Oversize tower)
5th Floor	*Laboratory (Expand existing)
4th Floor	*Radiology (Expand existing)
3rd Floor	*52 beds - OR & ICU (Expand existing)
2nd Floor	*Dining Room, Kitchen, Recreation (Expand existing)
1st Floor	*Administration, Emergency (Expand existing)

*NOTE: This expansion of existing facilities into new construction least hampers the existing hospital operation during construction; however, for alternate functional plans, whole existing area of Laboratory, Radiology, OR, and Kitchen can be abandoned and relocated.

DESIGN PLANNING

EXISTING BUILDING EXPANSION AND NEW CONSTRUCTION CRITERIA

1. Renovate the entire existing building as a minimum for life safety and electrical/mechanical update: 497,500 SF

Add new construction as follows: 402,711 SF

a. Nursing Tower and Ancillary 240,939 SF

b. Outpatient Building: 161,772 SF

Bldg dimensions are approximately:

$$370' \times 146' = 53,924 \text{ SF}$$

$$(\text{@3 floors} = 161,772 \text{ SF})$$

TOTAL 900,211 SF

2. Continue present floor heights into new construction - no ramps.

PORTSMOUTH		COMPARISON HOSPITALS			
FLOOR	FLOOR TO FLOOR HEIGHT				
15th	12'-0"				
14th	12'-0"				
13th	12'-0"				
12th	12'-0"				
11th	12'-0"				
10th	12'-0"				
9th	12'-0"				
8th	12'-0"		13'-6"		
7th	12'-0"		13'-6"	13'-0"	
6th	12'-0"		13'-6"	13'-0"	
5th	12'-0"	13'-4"	15'-2"	13'-0"	
4th	12'-0"	13'-4"	12'-8"	12'-0"	
3rd	14'-0"	15'-4"	15'-1"	16'-8"	18'-0"
		(mezz)			
2nd	14'-0"	15'-4"	15'-1"	16'-8"	16'-0"
1st	14'-0"	15'-4"	17'-0"	16'-8"	16'-0"
Crawl Space	5'-0"+		20'-0"		
		ORLANDO HOSP.	BREM. HOSP.	NURSING TOWER	ANCILLARY
				BETHESDA	

3. Utilize present ward area as able - possibly not O.P. completely - additional square footage needed by space requirements of new computer space program.
4. Add new 3-story O.P. building to west of present hospital and fill the space between proposed parking garage and existing hospital up to third or fourth floor level; possibly continue the north-south road under the new O.P. building, or design as 1974 master plan proposal by deleting the road and starting the O.P. building at grade level butting between the existing hospital and the proposed parking garage.

DD FORM 1391 5/N 0102-013-8001

19. (Continued)

Parking Structure - 850 vehicles
Support Facilities: Site preparation, road
revisions, sewer, water, storm drainage,
upgrading, landscaping, etc.

Material Transportation System - extend from
Fiscal and Supply Building to Building 215.